



1. Test objects

Power arc device:

Type:

SDI10.2

Tightening torque:

44Nm

No of pcs:

3

2. Testing procedure

The test procedure was acc. to standard.

The marking of the power arc device was rubbed by hand for 15 s with a piece of cloth soaked with water and another 15 s with a piece of cloth soaked with petroleum spirit.

The petroleum spirit used was Mineral turpentine from KILTO / Finland

Requirement:

The marking shall remain clear and allow the accessory to be easily identified.

3. Test results

The marking remained clear and was not at all affected of the rubbing.



Saves Your Energy


LABORATORY REPORT

No.: 2177S

Revision: A

Page: 3/3

4. Pictures



Picture 2: Markings after test

5. Test equipment

No special test equipment needed

6. Test Id

791

7. Revision history

A





Saves Your Energy

LABORATORY REPORT

No.: 2106S

Revision: A

Page: 1/4

Date of Test: 19.8.2010

Test object:

Tension clamp SO256.

Purpose of the test and relevant standards:

Part of type test.

Damage and failure load test for tension clamp according to EN 50397-2:2009 clause 7.4.1. Two samples were tested after gas atmosphere test (Method 2) done at Solar Simulator Finland acc. to EN 50397-2:2009 clause 7.10.1.2.2., test report: 050810_SO256_prohesion_test_Solar_TR.pdf and two samples were tested after climatic ageing test (Method 2) acc. to EN50397-2 clause 7.10.2.2., test report: 2191_SO256_UV_test_TR.docx.

Conclusion:

The clamp passed the test.



Picture 1: Tested clamp SO256

ENSTO
UTILITY NETWORKS
LABORATORY

Date of Report: 15.2.2011

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius
Distribution: OHL PD-team



Saves Your Energy

LABORATORY REPORT

No.: 2106S

Revision: A

Page: 2/4

1. Test objects

Clamp:

Type:	Tension clamp SO256
Batch number:	0-serie
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40 Nm
Clamp SMFL:	30 kN
No of pcs:	4

Conductors:

Type:	BLL-T 157
Used cross-section:	157 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	21,3 – 22,3 mm
Number of strands:	19
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Conductor MBL:	43,7 kN
Refer to standard:	EN50397-1



2. Testing procedure

The test was carried out as in Picture 2. The load was applied in the direction 1. The load was gradually increased until it reached the specified minimum damage load (SMDL). This load was kept constant for 60s. The fitting was then removed and measurement of any permanent deformation was done. The load was gradually increased until it reached the specified minimum failure load (SMFL). This load was kept constant for 60s.



Picture 2

Requirement:

Regarding damage load, the test is passed if no permanent deformation, which can affect the proper function of the fitting, occurs at or below the specified mechanical minimum damage load.

Regarding failure load, the test is passed if failure of the fitting does not occur at a load less than or equal to the specified minimum failure load.

3. Test results

Sample	Conductors	SMDL [kN]	SMFL [kN]	SMDL for 60s	SMFL for 60s	Remarks
1	BLL-T 157	27	30	Passed	Passed	Test piece from prohesion test
2	BLL-T 157	27	30	Passed	Passed	Test piece from prohesion test
3	BLL-T 157	27	30	Passed	Passed	Test piece from UV test
4	BLL-T 157	27	30	Passed	Passed	Test piece from UV test

Table 1: Test data

Summary:

All samples fulfilled standard requirements.



Saves Your Energy


LABORATORY REPORT

No.: 2106S

Revision: A

Page: 4/4

4. Pictures



Picture 1: Test arrangement

5. Test equipment


ID	TYPE	MODEL	PURPOSE
L110	Tensile test machine	50 kN	Tensile tests
L14	Torque wrench	BDS 80 E	Torque adjustment

6. Test Id

882

7. Revision history

A





Saves Your Energy

LABORATORY REPORT

No.: 1938S

Revision: A

Page: 1/4

Date of Test: 8.6 and 16.6.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Tensile test for tension clamps at ambient temperature according to EN 50397-2:2009 clause 7.4.7.

Conclusion:

The clamp passed the test.



Picture 1: Tested tension clamp SO256



Date of Report: 11.4.2011

Tested by: Patrick Ekholm

Witnessed by: Sami Hakonen / SGS Fimko

Reviewed by: Janne Lappalainen

Ordered by: V.Vilenius
Distribution: OHL PD-team



1. Test objects

Clamp:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40 Nm
Clamp SMFL:	30 kN
No of pcs:	6

Conductors:

Type:	SAX-W 95
Used cross-section:	95 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	16,1 mm
Number of strands:	7
Insulation material:	XLPE
Conductor material:	AlMgSi
Conductor MBL:	30,4 kN
Refer to standard:	EN50397-1

Type:	SAX-W 120
Used cross-section:	120 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	17,6 mm
Number of strands:	7
Insulation material:	XLPE
Conductor material:	AlMgSi
Conductor MBL:	38 kN
Refer to standard:	EN50397-1


Type:	SAX-W 150
Used cross-section:	150 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	18,9 mm
Number of strands:	19
Insulation material:	XLPE
Conductor material:	AlMgSi
Conductor MBL:	47,3 kN
Refer to standard:	EN50397-1



ВЯРНО С ОРИГИНАЛА

2. Testing procedure

Two tension clamps were installed in each end of the conductor, see Picture 2. The distance between clamps [1] was 100 x core diameter and the length of the tails [2] was approximately 500mm. The clamping pieces of the clamps were tightened to the nominal tightening torque. The arrangement was installed into a tensile test machine. The load of the arrangement was increased to 20% of SMFL. Then the conductor was marked at the end of the wedges. The load was then increased gradually until it reaches 60% of SMFL and kept there for 60s. After that the load was increased to SMFL and kept there for 60s. The load was then increased until failure occurred.



Picture 2

Requirement:

The test is passed if the movement of the conductor relative the clamp is less than 3 mm. Also no failure of the clamp or covered conductor occurs below the SMFL. $SMFL = 0,8 \times \text{conductor MBL}$.

Deviation

For some conductors the SMFL (80% of MBL) is higher than SMFL specified for the tension clamp. In these cases the SMFL specified for the tension clamp is used.

3. Test results

Sample	Conductors	MBL [kN]	20% of SMFL [kN]	60% of SMFL [kN]	SMFL [kN]	Result	Broke [kN]	Breaking point
1	SAX-W 95	30,4	4,86	14,59	24,32	OK	31,85	Conductor
2	SAX-W 95	30,4	4,86	14,59	24,32	OK		
3	SAX-W 120	38	6,08	18,24	30,4	OK	37,8	Clamp
4	SAX-W 120	38	6,08	18,24	30,4	OK		
13	SAX-W 150	47,3	6	18	30	OK	34	Clamp
14	SAX-W 150	47,3	6	18	30	OK		

Table 1: Test data

Summary: All samples fulfilled the test requirements.



4. Pictures



Picture 3: Test setup in tensile test machine

5. Test equipment

ID	TYPE	MODEL	PURPOSE
L110	Tensile test machine	50 kN	Tensile tests
L14	Torque wrench	BDS 80 E	Torque adjustment

6. Test Id

850

7. Revision history

A





Saves Your Energy

LABORATORY REPORT

No.: 1939S

Revision: A

Page: 1/5

Date of Test: 8.6.2010

Test object:


Waterproof tension clamp SO256.

Purpose of the test and relevant standards:

Tensile test for tension clamps at ambient temperature according to EN 50397-2:2009 clause 7.4.7.

Conclusion:

The tension clamp passed the test.



Picture 1: Tested tension clamp SO256

ENSTO
UTILITY NETWORKS
LABORATORY

Date of Report: 18.10.2010

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS
Fimko

Ordered by: V.Vilenius
Distribution: OHL PD-team



Saves Your Energy

LABORATORY REPORT

No.: 1939S

Revision: A

Page: 2/5

1. Test objects


Clamp:

Type:	Waterproof tension clamp SO256
Batch number:	0-serie
Conductor range:	95 – 157 mm ²
Tightening torque:	40 Nm
Clamp SMFL:	30 kN
No of pcs:	4

Conductors:


Type:	BLL-T 99
Used cross-section:	99 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	17,8 - 18,8 mm
Number of strands:	7
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Conductor MBL:	25,3 kN
Refer to standard:	EN50397-1

Type:	BLL-T 157
Used cross-section:	157 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	21,3 – 22,3 mm
Number of strands:	19
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Conductor MBL:	43,7 kN
Refer to standard:	EN50397-1



2. Testing procedure

Two tension clamps were tested for each conductor cross-section. The tension clamps were assembled upon the conductor according to manufacturers' instructions. The test arrangement can be seen in picture 2. The test load SMFL was $SMFL = 0,8 \times \text{conductor MBL}$. The load was increased to 20% of SMFL. Then the conductor was marked where it exits from the tension clamp. The load was then gradually increased to 60% of SMFL and kept there for 60 s. Without any subsequent adjustment of the fitting the load was increased to SMFL and kept there for 60 s. After this the tension clamps were then checked for any movement relative the conductor. Then the load was steadily increased until failure occurred. The failure load was recorded.



Picture 2: Tensile test arrangement

1. Min. 100 x covered conductor diameter
2. Length of tail 500mm

Requirement:

The movement of the tension clamp relative the conductor shall be less than 3 mm and no failure of the clamp or the cover conductor shall occur below SMFL.

3. Test results

Sample	Conductors	MBL [kN]	20% of SMFL [kN]	60% of SMFL [kN]	SMFL [kN]
7	BLL-T 99	25,3	4,05	12,14	20,24
8	BLL-T 99	25,3	4,05	12,14	20,24
9	BLL-T 157	43,7	7	20,98	34,96
10	BLL-T 157	43,7	7	20,98	34,96

Table 1: Tension during test



Saves Your Energy

LABORATORY REPORT

No.: 1939S

Revision: A

Page: 4/5


Sample	Conductors	Result	Broke [kN]	Breaking point
7	BLL-T 99	No slippage at SMFL	29,4	Conductor
8	BLL-T 99	No slippage at SMFL		
9	BLL-T 157	No slippage at SMFL	44,5	Clamp
10	BLL-T 157	No slippage at SMFL		

Summary: All samples fulfilled the test requirements.





4. Pictures



Picture 1: Sample in test

5. Test equipment

ID	TYPE	MODEL	PURPOSE
L109	Tensile test machine	170 kN	Tensile tests
L14	Torque wrench	BDS 80 E	Torque adjustment

6. Test Id

850

7. Revision history

A



Saves Your Energy

LABORATORY REPORT

No.: 2087S

Revision: A

Page: 1/5

Date of Test: 25.10 – 27.10.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Tensile test for tension clamp at low temperature according to EN 50397-2:2009 clause 7.4.8.

Conclusion:

The clamp passed the test.



Picture 1: Tested clamp SO256



Date of Report: 1.3.2011

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius

Distribution: OHL PD-team

Ensto Utility Networks Laboratory
Ensto Finland Oy

Ensio Miettien katu 2,
P.O.Box 77
06101 Porvoo, Finland

Tel +358 204 76 21
Fax +358 204 76 2770

Business ID: 0130215-8
Reg. Office: Porvoo





1. Test objects

Clamp:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
SMFL:	30kN (AlMgSi), 20kN (FeAl)
No of pcs:	6


Conductors:

Type:	BLL-T 99
Used cross-section:	99 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	17,8 – 18,8 mm
Number of strands:	7
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Conductor MBL:	25,3 kN
Refer to standard:	EN50397-1

Type:	BLL-T 157
Used cross-section:	157 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	21,3 – 22,3 mm
Number of strands:	19
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Conductor MBL:	43,7 kN
Refer to standard:	EN50397-1


2. Testing procedure

Three tension clamps were tested in low temperature zone, see Picture 2. The clamp and 300 mm of conductor [1] was cooled down to $(-25\pm3)^\circ\text{C}$.



Picture 2

Tension clamps were installed in each end of the conductor, see Picture 3. The distance between clamps [1] was approximately $100 \times$ core diameter and the length of the tails [2] was approximately 500mm. The clamping pieces of the clamps were tightened to the nominal tightening torque. Two arrangements were installed into a tensile test machine. The load of the arrangements was increased to 70% of conductor MBL. Three clamps were cooled down to $(-25\pm3)^\circ\text{C}$ in one hour and kept there for one hour. The tension was released. After the pre-tensioning the clamps were subjected to a 24h tensile test in low temperature, $(-25\pm3)^\circ\text{C}$. Before starting the test the load of the arrangements was increased to 20% of the specified minimum slip load. Then the conductor was marked at the end of the wedges. After marking the load was increased gradually until it reaches the specified minimum slip load and kept there for 24h.



Picture 3

Requirement:

The test is passed if the movement of the conductor relative the clamp is less than 3 mm at or below specified minimum slip load. Also no damage shall occur which could affect the correct function of the clamp.





3. Test results

Sample	Conductors	MBL [kN]	70% of MBL [kN]	20% of SMSL [kN]	SMSL [kN]	Result
7	BLL-T 99	25,3	17,7	3,2	15,8	No slippage
8	BLL-T 99	25,3	17,7	3,2	15,8	No slippage
9	BLL-T 99	25,3	17,7	3,2	15,8	No slippage
10	BLL-T 157	43,7	30,6	5,5	27,3	No slippage
11	BLL-T 157	43,7	30,6	5,5	27,3	No slippage
12	BLL-T 157	43,7	30,6	5,5	27,3	No slippage

Table 1: Test data


Specified minimum slip load (SMSL) = MBL / 1,6

Summary:

All samples fulfilled standard requirements.



4. Pictures



Picture 4: Test setup in tensile test machine

5. Test equipment


ID	TYPE	MODEL	PURPOSE
L14	Torque wrench	BDS 80 E	Torque adjustment
L110	Tensile test machine	50 kN	Tensile tests
C1	Cooling device -25°C	Ensto	Tensile test
C2	Cooling device -25°C	Ensto	Tensile test

6. Test Id

846

7. Revision history

A





Saves Your Energy

LABORATORY REPORT

No.: 2089S

Revision: A

Page: 1/5

Date of Test: 16.11, 24.11 and
21.12.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Tensile test for tension clamp at low temperature according to EN 50397-2:2009 clause 7.4.8.

Conclusion:

The clamp passed the test.



Picture 1: Tested clamp SO256



Date of Report: 1.3.2011

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius

Distribution: OHL PD-team



1. Test objects

Clamp:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
SMFL:	30kN (AlMgSi), 20kN (FeAl)
No of pcs:	9

Conductors:

Type:	PAS-W 95
Used cross-sections:	95 mm ²
Manufacturer/Country:	Draka NK Cables Oy / Finland
Insulation thickness:	2,8 mm
Total diameter:	17 mm
Number of strands:	7
Insulation material:	XLPE
Conductor material:	AlMgSi
Conductor MBL:	27,9 kN
Refer to standard:	EN50397-1


Type:	SAX-W 120
Used cross-sections:	120 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	17,6 mm
Number of strands:	19
Insulation material:	XLPE
Conductor material:	AlMgSi
Conductor MBL:	38 kN
Refer to standard:	EN50397-1

Type:	SAX-W 150
Used cross-section:	150 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	18,9 mm
Number of strands:	19
Insulation material:	XLPE
Conductor material:	AlMgSi
Conductor MBL:	47,3 kN
Refer to standard:	EN50397-1




2. Testing procedure

Three tension clamps were tested in low temperature zone, see Picture 2. The clamp and 300 mm of conductor [1] was cooled down to $(-25 \pm 3) ^\circ\text{C}$.



Picture 2

Tension clamps were installed in each end of the conductor, see Picture 3. The distance between clamps [1] was approximately $100 \times$ core diameter and the length of the tails [2] was approximately 500mm. The clamping pieces of the clamps were tightened to the nominal tightening torque. Two arrangements were installed into a tensile test machine. The load of the arrangements was increased to 70% of conductor MBL. Three clamps were cooled down to $(-25 \pm 3) ^\circ\text{C}$ in one hour and kept there for one hour. The tension was released. After the pre-tensioning the clamps were subjected to a 24h tensile test in low temperature, $(-25 \pm 3) ^\circ\text{C}$. Before starting the test the load of the arrangements was increased to 20% of the specified minimum slip load. Then the conductor was marked at the end of the wedges. After marking the load was increased gradually until it reaches the specified minimum slip load and kept there for 24h.



Picture 3

Requirement:

The test is passed if the movement of the conductor relative the clamp is less than 3 mm at or below specified minimum slip load. Also no damage shall occur which could affect the correct function of the clamp.



3. Test results

Sample	Conductors	MBL [kN]	70% of MBL [kN]	20% of SMSL [kN]	SMSL [kN]	Result
1	PAS-W 95	30,4	21,3	3,8	19	No slippage
2	PAS-W 95	30,4	21,3	3,8	19	No slippage
3	PAS-W 95	30,4	21,3	3,8	19	No slippage
13	SAX-W 120	38	26,6	4,75	23,75	No slippage
14	SAX-W 120	38	26,6	4,75	23,75	No slippage
15	SAX-W 120	38	26,6	4,75	23,75	No slippage
4	SAX-W 150	47,3	30*	5,9	29,56	No slippage
5	SAX-W 150	47,3	30*	5,9	29,56	No slippage
6	SAX-W 150	47,3	30*	5,9	29,56	No slippage

*The tensile force is restricted to clamp SMFL = 30kN

Table 1: Test data


Specified minimum slip load (SMSL) = $MBL / 1,6$

Summary:

All samples fulfilled standard requirements.



4. Pictures



Picture 4: Tension clamp in cooling device

5. Test equipment

ID	TYPE	MODEL	PURPOSE
L14	Torque wrench	BDS 80 E	Torque adjustment
L110	Tensile test machine	50 kN	Tensile tests
C1	Cooling device -25°C	Ensto	Tensile test
C2	Cooling device -25°C	Ensto	Tensile test

6. Test Id

846

7. Revision history

A



Saves Your Energy

LABORATORY REPORT

No.: 2091S

Revision: A

Page: 1/5

Date of Test: 17.6 – 12.7 and 19.8
– 12.9.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Tensile test for tension clamp at high temperature according to EN 50397-2:2009 clause 7.4.9.

Conclusion:

The clamp passed the test.



Picture 1: Tested clamp SO256



Date of Report: 1.3.2011

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius

Distribution: OHL PD-team

Ensto Utility Networks Laboratory
Ensto Finland Oy

Ensto Miettien katu 2,
P.O.Box 77
06101 Porvoo, Finland

Tel +358 204 76 21
Fax +358 204 76 2770

Business ID: 0130215-8
Reg. Office: Porvoo





1. Test objects

Clamp:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
SMFL:	30kN (AlMgSi), 20kN (FeAl)
No of pcs:	4

Conductors:

Type:	BLL-T 99
Used cross-section:	99 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	17,8 – 18,8 mm
Number of strands:	7
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Conductor MBL:	25,3 kN
Refer to standard:	EN50397-1

Type:	BLL-T 157
Used cross-section:	157 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	21,3 – 22,3 mm
Number of strands:	19
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Conductor MBL:	43,7 kN
Refer to standard:	EN50397-1




2. Testing procedure

The test was made with the maximum operating temperature of the conductor. Two tension clamps were tested. The test arrangement is shown in picture 2. The arrangement was installed in a horizontal test bench. A constant mechanical load was maintained throughout the test. The test load was 10% or 15% of conductor MBL. The test load was stabilised at $\pm 10\%$ and maintained for a period of at least 6 hours at ambient temperature. After the pre-tightening the test consisted of 100 heat cycles at a rate of maximum four cycles per day.

The heat cycle conditions:

- The conductor temperature was gradually increased to the maximum operating temperature of the conductor $\pm 5\text{ K}$, in less than 2 hours.
- The high temperature was maintained for 4 hours.
- The test arrangement was allowed to cool down to ambient temperature naturally.

The heating of the conductor was made with an AC transformer. The temperature of the conductor was measured underneath the covering with a thermocouple. The thermocouple was placed under the strands of the outer layer on the conductor.



Picture 2

Requirement:


The test is passed if no damage occurs which could affect the correct function of the clamp. Also no damage shall occur on the covering. The slippage of the covering shall be less than 20 mm.



3. Test results

Sample	Conductors	MBL [kN]	15% of MBL [kN]	Measured test load [kN]	Max operating temperature [°C]	Test current [A]	Result
7	BLL-T 99	25,3	3,8	3,95	70	343	Ok
8	BLL-T 99	25,3	3,8	3,95	70		
Sample	Conductors	MBL [kN]	10% of MBL [kN]	Measured test load [kN]	Max operating temperature [°C]	Test current [A]	Result
9	BLL-T 157	43,7	6,6	4,37	70	425	Ok
10	BLL-T 157	43,7	6,6	4,37	70		

Table 1: Test data




Graph 1: One heat cycle

Summary:

All samples fulfilled standard requirements.



4. Pictures



Picture 3: Test arrangement in vertical test bench

5. Test equipment


ID	TYPE	MODEL	PURPOSE
L14	Torque wrench	BDS 80 E	Torque adjustment
L56	Torque wrench	BDS 80 E	Torque adjustment
HT5	Test bench	Ensto	High temperature tests
HT6	Test bench	Ensto	High temperature tests
M1	AC Transformer	0 - 1000 A	AC-supply for heating
M12	AC Transformer	0 – 1500 A	AC-supply for heating

6. Test Id

849

7. Revision history

A





Saves Your Energy

LABORATORY REPORT

No.: 2092S

Revision: A

Page: 1/5

Date of Test: 19.8 – 12.9, 19.9 –
26.10 and 5.10 – 6.11.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Tensile test for tension clamp at high temperature according to EN 50397-2:2009 clause 7.4.9.

Conclusion:

The clamp passed the test.



Picture 1: Tested clamp SO256

ENSTO
UTILITY NETWORKS
LABORATORY

Date of Report: 1.3.2011

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius
Distribution: OHL PD-team



1. Test objects

Clamp:


Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
SMFL:	30kN (AlMgSi), 20kN (FeAl)
No of pcs:	6

Conductors:

Type:	SAX-W 95
Used cross-sections:	95 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	16,1 mm
Number of strands:	7
Insulation material:	XLPE
Conductor material:	AlMgSi
Conductor MBL:	30,4 kN
Refer to standard:	EN50397-1

Type:	SAX-W 120
Used cross-sections:	120 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	17,6 mm
Number of strands:	19
Insulation material:	XLPE
Conductor material:	AlMgSi
Conductor MBL:	38 kN
Refer to standard:	EN50397-1

Type:	SAX-W 150
Used cross-section:	150 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	18,9 mm
Number of strands:	19
Insulation material:	XLPE
Conductor material:	AlMgSi
Conductor MBL:	47,3 kN
Refer to standard:	EN50397-1




2. Testing procedure

The test was made with the maximum operating temperature of the conductor. Two tension clamps were tested. The test arrangement is shown in picture 2. The arrangement was installed in a horizontal test bench. A constant mechanical load was maintained throughout the test. The test load was 15% of conductor MBL. The test load was stabilised at $\pm 10\%$ and maintained for a period of at least 6 hours at ambient temperature. After the pre-tightening the test consisted of 100 heat cycles at a rate of maximum four cycles per day.

The heat cycle conditions:

- The conductor temperature was gradually increased to the maximum operating temperature of the conductor $\pm 5\text{ K}$, in less than 2 hours.
- The high temperature was maintained for 4 hours.
- The test arrangement was allowed to cool down to ambient temperature naturally.

The heating of the conductor was made with an AC transformer. The temperature of the conductor was measured underneath the covering with a thermocouple. The thermocouple was placed under the strands of the outer layer on the conductor.



Picture 2

Requirement:


The test is passed if no damage occurs which could affect the correct function of the clamp. Also no damage shall occur on the covering. The slippage of the covering shall be less than 20 mm.



3. Test results

Sample	Conductors	MBL [kN]	15% of MBL [kN]	Measured test load [kN]	Max operating temperature [°C]	Test current [A]	Result
1	SAX-W 95	30,4	4,6	4,517	80	338	Ok
2	SAX-W 95	30,4	4,6	4,517	80		
3	SAX-W 120	38	5,7	5,7	80	380	Ok
4	SAX-W 120	38	5,7	5,7	80		
5	SAX-W 150	47,3	7,1	7,1	80	402	Ok
6	SAX-W 150	47,3	7,1	7,1	80		

Table 1: Test data




Graph 1: One heat cycle

Summary:

All samples fulfilled standard requirements.



4. Pictures



Picture 3: Test arrangement in vertical test bench

5. Test equipment

ID	TYPE	MODEL	PURPOSE
L14	Torque wrench	BDS 80 E	Torque adjustment
L56	Torque wrench	BDS 80 E	Torque adjustment
HT5	Test bench	Ensto	High temperature tests
HT6	Test bench	Ensto	High temperature tests
M1	AC Transformer	0 - 1000 A	AC-supply for heating
M12	AC Transformer	0 - 1500 A	AC-supply for heating

6. Test Id

849

7. Revision history

A



Saves Your Energy

LABORATORY REPORT

No.: 2094S

Revision: A

Page: 1/4

Date of Test: 8.6.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Clamp bolt tightening test for tension clamp according to EN 50397-2:2009 clause 7.4.10.1 with deviation.

Conclusion:

The clamp passed the test.



Picture 1: Tested clamp SO256

ENSTO
UTILITY NETWORKS
LABORATORY

Date of Report: 18.5.2011

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius
Distribution: OHL PD-team

Ensto Utility Networks Laboratory
Ensto Finland Oy

Ensto Miettisen katu 2,
P.O.Box 77
06101 Porvoo, Finland

Tel. +358 204 76 21
Fax +358 204 76 2770

Business ID: 0130215-8
Reg. Office: Porvoo

ВЕРНО С ОРИГИНАЛОМ





1. Test objects

Clamp:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
No of pcs:	2

Conductors:

Type:	BLL-T 99
Used cross-section:	99 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	17,8 – 18,8 mm
Number of strands:	7
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1

Type:	BLL-T 157
Used cross-section:	157 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	21,3 – 22,3 mm
Number of strands:	19
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1



2. Testing procedure

Two clamps were tested. The clamp was installed on to the covered conductor. The tightening torque was increased to 1,1 x the specified installation torque. The clamp was checked for any damages. Then the tightening continued until breaking occurred. Breaking torque was recorded.

Deviation

Standard says that clamp shall be tightened and loosened 10 times to 1,1 x the specified installation torque. The clamps in test are tightened only ones because the clamps are not allowed to be re-used.

Requirement

No damage shall occur during tightening which could affect the correct function of the clamp or it's nuts.

3. Test results

Sample	Conductors	Tightening torque 44Nm [Nm]	Damage torque [Nm]
1	BLL-T 157	No damage	No damage at 100 Nm
2	BLL-T 99	No damage	No damage at 100 Nm

Table 1: Test data


Summary:

All samples fulfilled standard requirements.





4. Pictures



Picture 2: Test setup

5. Test equipment

ID	TYPE	MODEL	PURPOSE
L73	Torque wrench	Norbar 200	Torque adjustment
L14	Torque wrench	BDS – 80 E	Torque adjustment
L73	Torque wrench	Norbar 200	Torque adjustment

6. Test Id

852

7. Revision history

A



Saves Your Energy

LABORATORY REPORT

No.: 2095S

Revision: A

Page: 1/4

Date of Test: 8.6.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Clamp bolt tightening test for tension clamp according to EN 50397-2:2009 clause 7.4.10.1 with deviation.

Conclusion:

The clamp passed the test.



Picture 1: Tested clamp SO256

ENSTO
UTILITY NETWORKS
LABORATORY

Date of Report: 18.5.2011

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius

Distribution: OHL PD-team

Ensto Utility Networks Laboratory
Ensto Finland Oy

Ensto Miettisen katu 2,
P.O. Box 77
06101 Porvoo, Finland

Tel. +358 204 76 21
Fax +358 204 76 2770

Business ID: 0130215-8
Reg. Office: Porvoo

ВАРНО С ОПРИТЕЛНА





1. Test objects

Clamp:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
No of pcs:	2

Conductors:

Type:	SAX-W 95
Used cross-sections:	95 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	16,1 mm
Number of strands:	7
Insulation material:	XLPE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1

Type:	SAX-W 150
Used cross-section:	150 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	18,9 mm
Number of strands:	19
Insulation material:	XLPE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1



2. Testing procedure

Two clamps were tested. The clamp was installed on to the covered conductor. The tightening torque was increased to 1,1 x the specified installation torque. The clamp was checked for any damages. Then the tightening continued until breaking occurred. Breaking torque was recorded.

Deviation

Standard says that clamp shall be tightened and loosened 10 times to 1,1 x the specified installation torque. The clamps in test are tightened only ones because the clamps are not allowed to be re-used.

Requirement

No damage shall occur during tightening which could affect the correct function of the clamp or it's nuts.

3. Test results

Sample	Conductors	Tightening torque 44Nm [Nm]	Damage torque [Nm]
3	SAX-W 150	No damage	No damage at 100 Nm
4	SAX-W95	No damage	No damage at 100 Nm

Table 1: Test data

Summary:

All samples fulfilled standard requirements.



4. Pictures



Picture 2: Test setup

5. Test equipment

ID	TYPE	MODEL	PURPOSE
L73	Torque wrench	Norbar 200	Torque adjustment
L14	Torque wrench	BDS – 80 E	Torque adjustment
L73	Torque wrench	Norbar 200	Torque adjustment

6. Test Id

852

7. Revision history

A



Saves Your Energy

LABORATORY REPORT

No.: 2097S

Revision: A

Page: 1/4

Date of Test: 17.6.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Low temperature assembly test according to EN 50397-2:2009 clause 7.4.14.

Conclusion:

The clamp passed the test at -25 °C.



Picture 1: Tested clamp SO256

ENSTO
UTILITY NETWORKS
LABORATORY

Date of Report: 18.5.2011

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius

Distribution: OHL PD-team

Ensto Utility Networks Laboratory
Ensto Finland Oy

Ensto Miettisen katu 2,
P.O.Box 77
08101 Porvoo, Finland

Tel +358 204 76 21
Fax +358 204 76 2770

Business ID: 0130215-B
Reg. Office: Porvoo



ВАЖНО С ОРИГИНАЛА



1. Test objects

Clamp:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
No of pcs:	4

Conductors:

Type:	BLL-T 99
Used cross-section:	99 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	17,8 – 18,8 mm
Number of strands:	7
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1

Type:	BLL-T 157
Used cross-section:	157 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	21,3 – 22,3 mm
Number of strands:	19
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1



2. Testing procedure

The clamps and the conductors were pre-conditioned in a deep freezer until they reached the test temperature of $(-25 \pm 3)^{\circ}\text{C}$. The clamps were removed from the deep freezer and immediately tightening was carried out in a bench vice at a rate of approximately 1 full turn in 8 seconds. Electrical continuity was measured between the main and branch cables. The torque at which continuity was achieved was recorded. Two samples were tested for both minimum and maximum conductors.

Requirement:

Electrical continuity shall be achieved at a torque value less than, or equal to, 70 % of the manufacturer's specified minimum installation torque.

3. Test results

Sample	Conductors	Contact torque [Nm]
1	BLL-T 157	20
2	BLL-T 157	18
4	BLL-T 99	20
5	BLL-T 99	22

Table 1: Test data

Summary:

All samples fulfilled the requirement of the standard as none exceeded 28 Nm which is 70 % of the connectors tightening torque of 40 Nm.



4. Pictures



Picture 2: Test setup

5. Test equipment

ID	TYPE	MODEL	PURPOSE
L42	Thermometer	2455 16	Temperature measurements
L14	Torque wrench	BDS – 80 E	Torque adjustment
L60	Multimeter	Fluke 87	Voltage drop measurements
L33	Deep freezer	ALK 30	Climate testing

6. Test Id

1083

7. Revision history

A



Saves Your Energy

LABORATORY REPORT

No.: 2098S

Revision: A

Page: 1/4

Date of Test: 17.6.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Low temperature assembly test according to EN 50397-2:2009 clause 7.4.14.

Conclusion:

The clamp passed the test at -25 °C.



Picture 1: Tested clamp SO256

ENSTO
UTILITY NETWORKS
LABORATORY

Date of Report: 18.5.2011

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius
Distribution: OHL PD-team

Ensto Utility Networks Laboratory
Ensto Finland Oy

Ensto Miettisen katu 2,
P.O.Box 77
06101 Porvoo, Finland

Tel +358 204 76 21
Fax +358 204 76 2770

Business ID: 0130215-8
Reg. Office: Porvoo

ВАРНО С ОРИГИНАЛ





1. Test objects

Clamp:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
No of pcs:	4

Conductors:

Type:	SAX-W 95
Used cross-sections:	95 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	16,1 mm
Number of strands:	7
Insulation material:	XLPE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1

Type:	SAX-W 150
Used cross-section:	150 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	18,9 mm
Number of strands:	19
Insulation material:	XLPE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1



2. Testing procedure

The clamps and the conductors were pre-conditioned in a deep freezer until they reached the test temperature of $(-25 \pm 3)^{\circ}\text{C}$. The clamps were removed from the deep freezer and immediately tightening was carried out in a bench vice at a rate of approximately 1 full turn in 8 seconds. Electrical continuity was measured between the main and branch cables. The torque at which continuity was achieved was recorded. Two samples were tested for both minimum and maximum conductors.

Requirement:

Electrical continuity shall be achieved at a torque value less than, or equal to, 70 % of the manufacturer's specified minimum installation torque.

3. Test results

Sample	Conductors	Contact torque [Nm]
7	SAX-W 150	22
8	SAX-W 150	18
10	SAX-W 95	18
11	SAX-W 95	16

Table 1: Test data

Summary:

All samples fulfilled the requirement of the standard as none exceeded 28 Nm which is 70 % of the connectors tightening torque of 40 Nm.





4. Pictures



Picture 2: Test setup

5. Test equipment

ID	TYPE	MODEL	PURPOSE
L42	Thermometer	2455 16	Temperature measurements
L14	Torque wrench	BDS – 80 E	Torque adjustment
L60	Multimeter	Fluke 87	Voltage drop measurements
L33	Deep freezer	ALK 30	Climate testing

6. Test Id

1083

7. Revision history

A



Saves Your Energy

LABORATORY REPORT

No.: 2100S

Revision: A

Page: 1/4

Date of Test: 28 - 29.9.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Water tightness test according to EN 50397-2:2009 clause 7.6.

Conclusion:

The clamp passed the test.



Picture 1: Tested clamp SO256

Date of Report: 18.5.2011

Tested by: Patrick Ekholm

Witnessed by: Sami Hakonen / SGS Fimko

Reviewed by: Janne Lappalainen

Ordered by: V.Vilenius
Distribution: OHL PD-team

Ensto Utility Networks Laboratory
Ensto Finland Oy

Ensto Miettisen katu 2,
P.O.Box 77
06101 Porvoo, Finland

Tel +358 204 76 21
Fax +358 204 76 2770

Business ID: 0130215-8
Reg Office: Porvoo

ВАРНО С ОРИГИНАЛ





1. Test objects

Clamp:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
No of pcs:	6

Conductors:


Type:	BLL-T 99
Used cross-section:	99 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	17,8 – 18,8 mm
Number of strands:	7
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1

Type:	BLL-T 157
Used cross-section:	157 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	21,3 – 22,3 mm
Number of strands:	19
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1



2. Testing procedure

The clamps were installed onto the conductors according to manufactures instructions. One end rose over the water surface and the other end was plugged with an end cap. The clamps piercing parts were immersed in the water at a depth of 200mm. The clamps were kept in the water for 48 hours. Three samples were tested for minimum and maximum conductors.



Requirement:

No water shall penetrate to the conductor.


3. Test results

Sample	Conductors	Tightning torque [Nm]	Results
1	BLL-T 99	40	Ok
2	BLL-T 99	40	Ok
3	BLL-T 99	40	Ok
4	BLL-T 157	40	Ok
5	BLL-T 157	40	Ok
6	BLL-T 157	40	Ok

Table 1: Test data


Summary:

All samples fulfilled standard requirements.





4. Pictures



Picture 2: Test setup

5. Test equipment

ID	TYPE	MODEL	PURPOSE
L56	Torque wrench	BDS 80 E	Torque adjustment

6. Test Id

855

7. Revision history

A



Saves Your Energy

LABORATORY REPORT

No.: 2101S

Revision: A

Page: 1/4

Date of Test: 15-16.8 and 31.8-1.9.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Water tightness test according to EN 50397-2:2009 clause 7.6.

Conclusion:

The clamp passed the test.



Picture 1: Tested clamp SO256

ENSTO
UTILITY NETWORKS
LABORATORY

Date of Report: 18.5.2011

Tested by: Patrick Ekholm

Witnessed by: Sami Hakonen / SGS Fimko

Reviewed by: Janne Lappalainen

Ordered by: V.Vilenius
Distribution: OHL PD-team

Ensto Utility Networks Laboratory
Ensto Finland Oy

Ensto Miettisen katu 2,
P.O. Box 77
06101 Porvoo, Finland

Tel. +358 204 76 21
Fax +358 204 76 2770

Business ID: 0130215-8
Reg. Office: Porvoo

ВАРНО С ОПРАВИЛА





1. Test objects

Clamp:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
No of pcs:	6

Conductors:


Type:	SAX-W 95
Used cross-sections:	95 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	16,1 mm
Number of strands:	7
Insulation material:	XLPE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1

Type:	SAX-W 150
Used cross-section:	150 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	18,9 mm
Number of strands:	19
Insulation material:	XLPE
Conductor material:	AlMgSi
Refer to standard:	EN50397-1



2. Testing procedure

The clamps were installed onto the conductors according to manufactures instructions. One end rose over the water surface and the other end was plugged with an end cap. The clamps piercing parts were immersed in the water at a depth of 200mm. The clamps were kept in the water for 48 hours. Three samples were tested for minimum and maximum conductors.



Requirement:

No water shall penetrate to the conductor.

3. Test results

Sample	Conductors	Tightning torque [Nm]	Results
7	SAX-W 95	40	Ok
8	SAX-W 95	40	Ok
9	SAX-W 95	40	Ok
10	SAX-W 150	40	Ok
11	SAX-W 150	40	Ok
12	SAX-W 150	40	Ok

Table 1: Test data


Summary:

All samples fulfilled standard requirements.





4. Pictures



Picture 2: Test setup

5. Test equipment

ID	TYPE	MODEL	PURPOSE
L56	Torque wrench	BDS 80 E	Torque adjustment

6. Test Id

855

7. Revision history

A



Saves Your Energy

LABORATORY REPORT

No.: 2103S

Revision: A

Page: 1/5

Date of Test: 29.9.2010

Test object:

Tension clamp SO256 and power arc device SDI27.1.


Purpose of the test and relevant standards:

Part of type test.

Short-circuit test according to EN 50397-2:2009 clause 7.8.

Conclusion:

The clamp and power arc device passed the test.



Picture 1: Tested clamp SO256 and power arc device SDI27.1



Date of Report: 1.3.2011

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius

Distribution: OHL PD-team

Ensto Utility Networks Laboratory
Ensto Finland Oy

Ensto Miettisen katu 2,
P.O.Box 77
06101 Porvoo, Finland

Tel +358 204 76 21
Fax +358 204 76 2770

Business ID: 0130215-8
Reg. Office: Porvoo

ВАРНО С ОРИГИНАЛ





1. Test objects

Clamps:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
SMFL:	30kN (AlMgSi), 20kN (FeAl)
No of pcs:	6

Type:	Power arc device SDI27.1
Batch number:	0-series
Tightening torque:	44Nm
No of pcs:	6


Conductors:

Type:	BLL-T 157
Used cross-section:	157 mm ²
Manufacturer/Country:	AMO Kraft AB / Sweden
Insulation thickness:	2,5 mm
Total diameter:	21,3 – 22,3 mm
Number of strands:	19
Insulation material:	HDPE+PE
Conductor material:	AlMgSi
Max. short circuit current:	15,3 kA (+50°C >> +250°C)
Refer to standard:	EN50397-1



2. Testing procedure

Three test arrangements shall be tested. The test arrangement is subjected to one 10kA pulse of over-current for 1s. The test arrangement is shown in Picture 2. For this test the earthing rod will be replaced by a straight piece of the same cross-section, shape and material as the earthing rod. The test arrangement is made of two clamps installed on maximum conductor and combined with a test rod. The resistances are measured over reference conductor and the connectors before and after the test.



- 1 Resistance measurement reference conductor
- 2 Resistance measurement clamp
- 3 Resistance measurement clamp
- 4 Test rod twice the length of earthing rod

Picture 2: Test arrangement

Requirement:

The change of resistance before and after short circuit shall be less than 50 %. No visible damage shall be observed on the connector or on the cable.





3. Test results

Sample	Lenght [mm]		Resistance before [$\mu\Omega$]			Resistance after [$\mu\Omega$]			Change in resistance	Over-current
	Reference	Clamp	Reference	Between measuring points	Clamp	Reference	Between measuring points	Clamp		
7	541	439	114	295	202	113	273	181	-10 %	10,9 kA
8	541	440	114	302	209	113	272	180	-14 %	10,9 kA
9	519	440	108	290	198	107	271	180	-9 %	10,9 kA
10	519	453	108	323	229	107	286	193	-16 %	10,9 kA
11	484	429	97	299	213	97	269	183	-14 %	10,9 kA
12	484	425	97	291	206	97	274	189	-8 %	10,9 kA


Table 1: Test data

Summary:

All samples fulfilled standard requirements.



4. Pictures



Picture 3: Test setup

5. Test equipment

ID	TYPE	MODEL	PURPOSE
SM3	Short-circuit transformer	230 kVA	Supply for s-c test
L160	Analog input/output module	cFP-AIO-610	DC-current measurement
L163	Thermocouple module	cFP-TC-125	Voltage drop measurements
L164	Thermocouple module	cFP-TC-125	Voltage drop measurements
L56	Torque wrench	BDS 80 E	Torque adjustment
L68	Scopemeter	105B	Short-circuit characteristics

6. Test Id

856

7. Revision history

A





Saves Your Energy

LABORATORY REPORT

No.: 2104S

Revision: A

Page: 1/5

Date of Test: 29.9.2010

Test object:

Tension clamp SO256 and power arc device SDI27.1.


Purpose of the test and relevant standards:

Part of type test.

Short-circuit test according to EN 50397-2:2009 clause 7.8.

Conclusion:

The clamp and power arc device passed the test.



Picture 1: Tested clamp SO256 and power arc device SDI27.1

Date of Report: 1.3.2011

Tested by: Patrick Ekholm

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius

Distribution: OHL PD-team



Saves Your Energy

LABORATORY REPORT

No.: 2104S

Revision: A

Page: 2/5

1. Test objects

Clamps:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40Nm
SMFL:	30kN (AlMgSi), 20kN (FeAl)
No of pcs:	6

Type:	Power arc device SDI27.1
Batch number:	0-series
Tightening torque:	44Nm
No of pcs:	6


Conductors:

Type:	SAX-W 150
Used cross-section:	150 mm ²
Manufacturer/Country:	Prysmian / Finland
Insulation thickness:	2,4 mm
Total diameter:	18,9 mm
Number of strands:	19
Insulation material:	XLPE
Conductor material:	AlMgSi
Max. short circuit current:	13,5 kA (+40°C >> +200°C)
Refer to standard:	EN50397-1



2. Testing procedure

Three test arrangements shall be tested. The test arrangement is subjected to one 10kA pulse of over-current for 1s. The test arrangement is shown in Picture 2. For this test the earthing rod will be replaced by a straight piece of the same cross-section, shape and material as the earthing rod. The test arrangement is made of two clamps installed on maximum conductor and combined with a test rod. The resistances are measured over reference conductor and the connectors before and after the test.



- 1 Resistance measurement reference conductor
- 2 Resistance measurement clamp
- 3 Resistance measurement clamp
- 4 Test rod twice the length of earthing rod

Picture 2: Test arrangement

Requirement:

The change of resistance before and after short circuit shall be less than 50 %. No visible damage shall be observed on the connector or on the cable.



Saves Your Energy

LABORATORY REPORT

No.: 2104S

Revision: A

Page: 4/5

3. Test results

Sample	Lenght [mm]		Resistance before [$\mu\Omega$]			Resistance after [$\mu\Omega$]			Change in resistance	Over-current
	Reference	Clamp	Reference	Between measuring points	Clamp	Reference	Between measuring points	Clamp		
1	505	445	112	279	180	113	277	177	-2 %	10,2 kA
2	505	450	112	283	183	113	280	179	-2 %	10,2 kA
3	507	436	112	283	187	113	277	180	-4 %	10,2 kA
4	507	434	112	302	206	113	287	190	-8 %	10,2 kA
5	513	448	113	300	201	113	275	176	-12 %	10,2 kA
6	513	428	113	287	193	113	275	181	-6 %	10,2 kA


Table 1: Test data

Summary:

All samples fulfilled standard requirements.



4. Pictures



Picture 3: Test setup

5. Test equipment

ID	TYPE	MODEL	PURPOSE
SM3	Short-circuit transformer	230 kVA	Supply for s-c test
L160	Analog input/output module	cFP-AIO-610	DC-current measurement
L163	Thermocouple module	cFP-TC-125	Voltage drop measurements
L164	Thermocouple module	cFP-TC-125	Voltage drop measurements
L56	Torque wrench	BDS 80 E	Torque adjustment
L68	Scopemeter	105B	Short-circuit characteristics

6. Test Id

856

7. Revision history

A



Solar Simulator
Solar Simulator Finland Ltd.

Test Report
Confidential
1/5

ref.no.: SO256_EnstoSekkoLappalainentr240610TO.pdf

● Venus Greenhouse Test

Customer:



Ensto Sekko Oy
Janne Lappalainen
P.O. Box 51
FI-06101 Porvoo

Research Contract:

EnstoSekkoLappalainenso171209HS.pdf
Ensto Test Id: 841 / 14.5.2010

Target:

Test item	Code	Manufacturer	Q'ty
Tension clamp	SO256	Ensto UN	2

Picture of the tested sample has been taken before the test.



Testing time:

The start of the test: 24th of June, 2010
The end of the test: 5th of August, 2010
Total test time 1000 hours

Purpose of the test:

To test the withstand of the samples to prohesion mist spray.


Test method:

The strain of the test is made according to the standard EN 50483-6 8.4.2.2 Gas atmosphere (Method 2). The test is a prohesion test. The test cycle consists of 0.05 % NaCl and 0.35 % (NH₄)₂SO₄ salt mist at the ambient temperature of 25 ± 3°C for one hour and one hour long drying time at the ambient temperature of 35°C. This test cycle is repeated for 500 times.

Validation of test method:

The test method was defined according to the requirements of the customer.

The test is used for comparative test of materials. The test conditions have some correlation with the real life conditions because the salt concentration is not very high. However, at the end of the drying period the concentration of the salt solution is very high.



Keskiläntie 5
FI-20660 Littoinen

Tel. +358 (0)2 474 1600
Fax +358 (0)2 474 1629

ID 1045853-3
www.solarsimulator.com


Actions done:

The samples were attached to a test casing after which the samples were placed into a prohesion mist chamber. The prohesion liquid solution was made to a purified water by using pro analysi sodium chloride and pro analysi ammonium sulphate. The amount of total impurities in the used salts was max. 0.5 % (in the standard 0.3 %). The pH of the solution was measured with a pH-meter to be 5.4. On a separate test a collecting receptacle with a collecting surface of 80 cm² collected 2 ml of prohesion solution per hour averaged over a period of 16 hours.

The samples were attached with plastic cable ties to the sample stand. The angle of the sample stand was 60° from horizontal. The sample was situated into a test chamber and the test lasted for 1000 hours.

The samples were photographed at an interval of one test week. After the test the samples were washed in running tap water for five minutes. The temperature of the tap water was 30°C. After that the samples were rinsed in distilled water and then dried with an air blast.

The ambient temperature and relative humidity in the test chamber during 12 test cycles is presented in the figure.









Solar Simulator
Solar Simulator Finland Ltd.

Test Report
Confidential
3/5

ref.no.: SO256_EnstoSekkoLappalainenr240610TO.pdf

Tension clamp, SO256, Samples A and B, Ensto UN (Pictures of the sample were taken: From top: before the test, after one week, after two weeks, after three weeks, after four weeks, after five weeks, after the test and after washing the sample.)









Solar Simulator
Solar Simulator Finland Ltd.

Test Report
Confidential
4/5

ref.no.: SO256_EnstoSekkoLappalainentr240610TO.pdf





Solar Simulator
Solar Simulator Finland Ltd.

Test Report
Confidential
5/5

ref.no.: SO256_EnstoSekkoLappalainenr240610TO.pdf

Conclusions:

The strain for the samples was prohesion mist.

The degradation in the samples was restricted only to the top layers of the cover parts of the samples.

The **SO256** samples made by Ensto UN passed the visual test.

Analysis:

Remarks:

Samples were photographed at an interval of one test week. The photographs were sent by email to the customer.

Used measuring equipment:

Prohesion chamber, No. 22

Temperature: No. 42 / Ch4_T1, calibrated 28th June, 2010, calibration is valid


Humidity: No. 42 / RH_AUX, calibrated 28th June, 2010, calibration is valid

pH: Fastech FT11, calibrated 28th June, 2010, calibration is valid

Actions, operations and reporting are in accordance with IEC/ISO 17025 'General requirements for the competence of testing laboratories'.

Signatures:

Timo Oksa
Littoinen, 5th of August, 2010



Venus Greenhouse Test

Customer:



Ensto Finland Oy
Janne Lappalainen
P.O. Box 51
FI-06101 Porvoo

Research Contract:

EnstoSekkoLappalainenso171209HS.pdf
Ensto Test Id: 1012, 20.10.2010

Target:

Test item	Code	Manufacturer	Q'ty
Conductor with cable lugs for arc protection kit	SDI27.1	Ensto UN	1

Picture of the tested sample has been taken before the test.



Testing time:

The start of the test: 22nd of October, 2010
The end of the test: 3rd of December, 2010
Total test time 1000 hours

Purpose of the test:

To test the withstand of the samples to prohesion mist spray.

Test method:

The strain of the test is made according to the standard EN 50483-6, 8.4.2.2 Gas atmosphere (Method 2). The test is a prohesion test. The test cycle consists of 0.05 % NaCl and 0.35 %



Solar Simulator

Solar Simulator Finland Ltd.

Test Report

Confidential

2/5

ref.no.: ConductorKit_EnstoFinlandLappalainen__tr221010TO.pdf

(NH₄)₂SO₄ salt mist at the ambient temperature of 24 ± 3 °C for one hour and one hour long drying time at the ambient temperature of 35 °C. This test cycle is repeated for 500 times.

Validation of test method:

The test method was defined according to the requirements of the customer.

The test is used for comparative test of materials. The test conditions have some correlation with the real life conditions because the salt concentration is not very high. However, at the end of the drying period the concentration of the salt solution is very high.


Actions done:

The samples were attached to a test casing after which the samples were placed into a prohesion mist chamber. The prohesion liquid solution was made to a purified water by using pro analysi sodium chloride and pro analysi ammonium sulphate. The amount of total impurities in the used salts was max. 0.5 % (in the standard 0.3 %). The pH of the solution was measured with a pH-meter to be 5.4. On a separate test a collecting receptacle with a collecting surface of 80 cm² collected 2 ml of prohesion solution per hour averaged over a period of 16 hours.

The samples were attached with plastic cable ties to the sample stand. The angle of the sample stand was 60° from horizontal. The sample was situated into a test chamber and the test lasted for 1000 hours.

The samples were photographed at an interval of one test week. After the test the samples were washed in running tap water for five minutes. The temperature of the tap water was 30 °C. After that the samples were rinsed in distilled water and then dried with an air blast.

The ambient temperature and relative humidity in the test chamber during a cycle of 24 hours is presented in the figure.





Solar Simulator

Solar Simulator Finland Ltd.






Test Report

Confidential

3/5

ref.no.: ConductorKit_EnstoFinlandLappalainen__tr221010TO.pdf

Conductor with cable lugs for arc protection kit SDI27.1, Ensto UN (Pictures of the sample were taken: From top till bottom row: before the test, after one week, after two weeks, after three weeks, after four weeks, after five weeks, after the test and after washing the sample.)





Solar Simulator





Solar Simulator Finland Ltd.

Test Report

Confidential

4/5

ref.no.: ConductorKit_EnstoFinlandLappalainen_tr221010TO.pdf



Keskiläntie 5
FI-20660 Littoinen

Tel. +358 (0)2 474 1600
Fax +358 (0)2 474 1629

ID 1045853-3
www.solarsimulator.com



Solar Simulator
Solar Simulator Finland Ltd.

Test Report
Confidential
5/5

ref.no.: ConductorKit_EnstoFinlandLappalainen_tr221010TO.pdf

Conclusions:

The strain for the samples was 1000 h of prohesion mist.

There was minor degradation observed in the cable lugs. The **SDI27.1** passed the visual test.

Analysis:

Remarks:

Samples were photographed at an interval of one test week. The photographs were sent by email to the customer.

Used measuring equipment:

Prohesion chamber, No. 22

Temperature: No. 42 / Ch4_T1, calibrated 28th June, 2010, calibration is valid

Humidity: No. 42 / RH_AUX, calibrated 28th June, 2010, calibration is valid

pH: No. 41, Fastech FT11, calibrated 28th June, 2010, calibration is valid

Actions, operations and reporting are in accordance with IEC/ISO 17025 'General requirements for the competence of testing laboratories'.

Signatures:

Timo Oksa
Littoinen, 7th of December, 2010





Solar Simulator
Solar Simulator Finland Ltd.

Test Report
Confidential
1/5

ref.no.: TestId1080_EnstoFinlandLappalainen_tr050111.pdf

● Venus Greenhouse Test

Customer:



Ensto Finland Oy
Janne Lappalainen
P.O. Box 51
FI-06101 Porvoo

Research Contract:

EnstoFinlandLappalainen__ta141210HS.pdf
2828_001 / 14.12.2010
Ensto Test Id: 1080, 4.1.2011

Target:

Test item	Code	Q'ty	Manufacturer
Power arc device	SDI10.2	2	Ensto UN

Picture of one of the tested samples has been taken before the test.



Testing time:

The start of the test: 5th of January, 2011
The end of the test: 16th of February, 2011
Total test time 1000 hours

Purpose of the test:

To test the withstand of the samples to prohesion mist spray.

Test method:

The strain of the test is made according to the standard EN 50483-6, 8.4.2.2 Gas atmosphere (Method 2). The test is a prohesion test. The test cycle consists of 0.05 % NaCl and 0.35 % (NH₄)₂SO₄ salt mist at the ambient temperature of 24 ± 3°C for one hour and one hour long drying time at the ambient temperature of 35°C. This test cycle is repeated for 500 times.



**Validation of test method:**

The test method was defined according to the requirements of the customer.

The test is used for comparative test of materials. The test conditions have some correlation with the real life conditions because the salt concentration is not very high. However, at the end of the drying period the concentration of the salt solution is very high.


Actions done:

The samples were attached to a test casing after which the samples were placed into a prohesion mist chamber. The prohesion liquid solution was made to a purified water by using pro analysi sodium chloride and pro analysi ammonium sulphate. The amount of total impurities in the used salts was max. 0.5 % (in the standard 0.3 %). The pH of the solution was measured with a pH-meter to be 5.5. On a separate test a collecting receptacle with a collecting surface of 80 cm² collected 2 ml of prohesion solution per hour averaged over a period of 16 hours.

The samples were attached with plastic cable ties to the sample stand. The angle of the sample stand was 60° from horizontal. The sample stand was situated into a test chamber and the test lasted for 1000 hours.

The samples were photographed at an interval of one test week. After the test the samples were washed in running tap water for five minutes. The temperature of the tap water was 30°C. After that the samples were rinsed in purified water and then dried with an air blast.

The ambient temperature and relative humidity in the test chamber during a cycle of 24 hours is presented in the figure.





Solar Simulator

Solar Simulator Finland Ltd.


Test Report

Confidential

3/5

ref.no.: TestId1080_EnstoFinlandLappalainen_tr050111.pdf


Power arc device SDI10.2, Sample A (Pictures of the sample were taken: Top row: before the test, after one week and after two weeks, Middle row: after three weeks, after four weeks and after five weeks, Bottom row: after the test and after washing the sample.)



Keskiläntie 5
FI-20660 Littoinen

Tel. +358 (0)2 474 1600
Fax +358 (0)2 474 1629

ID 1045853-3
www.solarsimulator.com




Solar Simulator
Solar Simulator Finland Ltd.

Test Report
Confidential
4/5

ref.no.: TestId1080_EnstoFinlandLappalainen_tr050111.pdf

Power arc device SDI10.2, Sample B (Pictures of the sample were taken: Top row: before the test, after one week and after two weeks, Middle row: after three weeks, after four weeks and after five weeks, Bottom row: after the test and after washing the sample.)





Solar Simulator

Solar Simulator Finland Ltd.

Test Report

Confidential

5/5

ref.no.: TestId1080_EnstoFinlandLappalainen_tr050111.pdf

Conclusions:

The strain for the samples was 1000 h of prohesion mist.

The power arc device **SDI10.2** passed the visual test.

Analysis:

Remarks:

Samples were photographed at an interval of one test week. The photographs were sent by email to the customer.

Used measuring equipment:

Prohesion chamber, No. 22

Temperature: No. 42 / Ch4_T1, calibrated 21st January, 2011, calibration is valid

Humidity: No. 42 / RH_AUX, calibrated 21st January, 2011, calibration is valid

pH: No. 41, Fastech FT11, calibrated 21st January, 2011, calibration is valid


Actions, operations and reporting are in accordance with IEC/ISO 17025 'General requirements for the competence of testing laboratories'.

Signatures:

Timo Oksa
Littoinen, 16th of February, 2011



CORROSION





Saves Your Energy

LABORATORY REPORT

No.: 2191S

Revision: A

Page: 1/5

Date of Tests: 28.6.-9.8.2010

Test object:

Tension clamp SO256.


Purpose of the test and relevant standards:

Part of type test.

Climatic ageing test, method 2 (UV-test), according to EN 50397-2:2009, clause 7.10.2.2.

Conclusion:

The tension clamp passed the test.



Picture 1: Tested product SO256.



Date of Report: 8.6.2011

Tested by: Kari Malinen

Reviewed by: Janne Lappalainen

Witnessed by: Sami Hakonen / SGS Fimko

Ordered by: V.Vilenius
Distribution: OHL PD-team

Ensto Utility Networks Laboratory
Ensto Finland Oy

Ensto Miettisen katu 2,
P.O.Box 77
06101 Porvoo, Finland

Tel +358 204 76 21
Fax +358 204 76 2770

Business ID: 0130215-8
Reg. Office: Porvoo



Saves Your Energy

LABORATORY REPORT

No.: 2191S

Revision: A

Page: 2/5

1. Test object

Tension clamp:

Type:	Tension clamp SO256
Batch number:	0-series
Conductor range:	95 – 157 mm ²
Conductor diameter:	16,1 – 22,3 mm
Tightening torque:	40 Nm
Clamp SMFL:	30 kN
No of pcs:	2



2. Testing procedure


2.1 Simulated solar radiation test (UV-test)

The test was carried out in an enclosure, where an irradiance of 0,83 kW/m² with the spectral distribution given in Table 1 was provided over an irradiation measurement plane of 900 mm x 900 mm. This value includes any radiation reflected from the test enclosure. The radiation was produced with 20 pcs of 300 W Ultra-Vitalux lamps of Osram with burning age (50%) 1000 h. The distance to the measurement plane was 700 mm.

The test consists of 56 daily cycles (8 weeks). Each cycle consist of 20 h irradiation and 4 h darkness, Picture 2. The temperature was maintained at 55±2 °C during the irradiation period and at 25±2 °C during the darkness period. The temperature was measured with a thermocouple in a point 40 mm below the measurement plane at half the distance between the specimen and the wall.

Spectral region	Ultra-violet B	Ultra-violet A	Visible			Infra-red
Bandwidth	0,28 µm - 0,32 µm	0,32 µm - 0,40 µm	0,40 µm - 0,52 µm	0,52 µm - 0,64 µm	0,64 µm - 0,78 µm	0,78 µm - 3,00 µm
Irradiance measured	9,1 W/m ²	47,3 W/m ²	53,0 W/m ²	105,1 W/m ²	33,3 W/m ²	578,6 W/m ²
Std. requirements Irradiance Tolerance	5 W/m ² ±35 %	63 W/m ² ±25 %	200 W/m ² ±10 %	186 W/m ² ±10 %	174 W/m ² ±10 %	492 W/m ² ±20 %

Table 1: Spectral energy distribution and permitted tolerances



Picture 2: Temperature-radiation-time relationships



Saves Your Energy

LABORATORY REPORT

No.: 2191S

Revision: A

Page: 4/5

Requirements

Simulated solar radiation test (UV-test)

The sample may not have any degradation, which could affect the normal function and the identification marking shall be legible.

Damage and failure load test

Regarding damage load, the test is passed if no permanent deformation, which can affect the proper function of the fitting, occurs at or below the specified mechanical minimum damage load.

Regarding failure load, the test is passed if failure of the fitting does not occur at a load less than or equal to the specified minimum failure load.

3. Test results

Test results for damage and failure load test can be founded in test report:
2106_SO256_Damage_and_failure_load_test_TR.pdf


Summary:

No visual degradation could be noticed. The markings are clearly legible.







4. Pictures



Picture 2: Tension clamps before test.



Picture 3: Sample 1 after test.



Picture 4: Sample 2 after test.

5. Test equipment

ID	TYPE	MODEL	PURPOSE
UV1	UV-radiation chamber	Ensto	Climate testing
L112	Thermometer	Center 309	Temperature measurements

6. Test Id

882

7. Revision history

A



Saves Your Energy

LABORATORY REPORT

No.: 2170S

Revision: A

Page: 1/6

Date of Tests: 8.7.-1.9.2010

Test object:

End cap ENSTO PMR2720.


Purpose of the test and relevant standards:

Part of type test.

Climatic ageing test, method 2 (UV-test), according to EN 50397-2:2009, clause 7.11.2.3.2.

Conclusion:

The end cap passed the test.



Picture 1: Tested product PMR2720.

ENSTO
UTILITY NETWORKS
LABORATORY

Date of Report: 23.5.2011

Tested by: Kari Malinen

Witnessed by: Sami Hakonen / SGS Fimko

Reviewed by: Janne Lappalainen

Ordered by: M.Salonen
Distribution: MSa, VV

Ensto Utility Networks Laboratory
Ensto Finland Oy

Ensto Miettisen katu 2,
P.O.Box 77
06101 Porvoo, Finland

Tel +358 204 76 21
Fax +358 204 76 2770

Business ID 0130215-8
Reg Office: Porvoo



ВЯРНО С ОРИГИНАЛОМ



Saves Your Energy

LABORATORY REPORT

No.: 2170S

Revision: A

Page: 2/6

1. Test object

End cap:

Product code: PMR2720

Cross-section: 12,7 – 22,3 mm

No of pcs: 2



2. Testing procedure


2.1 Simulated solar radiation test (UV-test)

The test was carried out in an enclosure, where an irradiance of $0,83 \text{ kW/m}^2$ with the spectral distribution given in Table 1 was provided over an irradiation measurement plane of $900 \text{ mm} \times 900 \text{ mm}$. This value includes any radiation reflected from the test enclosure. The radiation was produced with 20 pcs of 300 W Ultra-Vitalux lamps of Osram with burning age (50%) 1000 h. The distance to the measurement plane was 700 mm.


The test consists of 56 daily cycles (8 weeks). Each cycle consist of 20 h irradiation and 4 h darkness, Picture 2. The temperature was maintained at $55 \pm 2^\circ \text{C}$ during the irradiation period and at $25 \pm 2^\circ \text{C}$ during the darkness period. The temperature was measured with a thermocouple in a point 40 mm below the measurement plane at half the distance between the specimen and the wall.

Spectral region	Ultra-violet B	Ultra-violet A	Visible			Infra-red
Bandwidth	0,28 μm - 0,32 μm	0,32 μm - 0,40 μm	0,40 μm - 0,52 μm	0,52 μm - 0,64 μm	0,64 μm - 0,78 μm	0,78 μm - 3,00 μm
Irradiance measured	9,1 W/m^2	47,3 W/m^2	53,0 W/m^2	105,1 W/m^2	33,3 W/m^2	578,6 W/m^2
Std. requirements Irradiance Tolerance	5 W/m^2 $\pm 35\%$	63 W/m^2 $\pm 25\%$	200 W/m^2 $\pm 10\%$	186 W/m^2 $\pm 10\%$	174 W/m^2 $\pm 10\%$	492 W/m^2 $\pm 20\%$

Table 1: Spectral energy distribution and permitted tolerances



Picture 2: Temperature-radiation-time relationships





Requirements

Simulated solar radiation test (UV-test)

The sample may not have any degradation, which could affect the normal function and the identification marking shall be legible.

3. Test results

Summary:

The samples have small cracks on the upper surface, but in fact these have no influence to proper working of the end cap. The markings are clearly legible.



Saves Your Energy


LABORATORY REPORT

No.: 2170S

Revision: A

Page: 5/6


4. Pictures



Picture 2: End cap before UV-test.



Picture 3: End cap after Uv-test.



Picture 4: Markings on the end cap.





5. Test equipment

ID	TYPE	MODEL	PURPOSE
UV1	UV-radiation chamber	Ensto	Climate testing
L112	Thermometer	Center 309	Temperature measurements

6. Test Id

838

7. Revision history

A

TEST REPORT

IEC 61238-1

Compression and mechanical connectors for power cables

Part 1: Test method and requirements

Report

Reference No.: 251420-1

Compiled by (+ signature): S.Hakonen

Approved by (+ signature): V.Haapaoja

Date of issue: 16.05.2008

Contents: 9 pages including Annex

This report is based on a blank test report that was prepared by SGS Fimko.



Testing laboratory

Name: SGS Fimko Ltd.

Address: P.O. Box 30, FIN-00211 HELSINKI, FINLAND

Testing location: Särkiniementie 3, FIN-00210 HELSINKI, FINLAND

Client

Name: Ensto Sekko

Address: Ensio Miettisen katu 2

.....: FI-06100 PORVOO, FINLAND

Test specification

Standard: IEC 61238-1:2003

Test procedure: FI-Scheme

Procedure deviation: N.A.

Non-standard test method: N.A.

Test Report Form / blank test report

Test Report Form No.: IEC 61238-1_SGS FIMKO

TRF: SGS Fimko Ltd

Copyright © 2002 SGS Fimko Ltd / IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

Test item description: Connector for power cables

Trademark: **ENSTO**

Manufacturer: Ensto Sekko

Model and/or type reference: SML1.17

Rating(s): Al/Cu 10 – 95 mm²



Copy of marking plate

ENSTO

SML1.17

Summary of testing and remarks

Connector SML1.17 fulfils requirements of the standard.

Heat cycle test made with Al 95 mm² conductor and d.c current.

General remarks

This test report shall not be reproduced except in full without the written approval of the testing laboratory.

The test results presented in this report relate only to the item tested.

"(see remark #)" refers to a remark appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.

This document is issued by the company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated: (a) the results shown in this document refer only to the sample(s) tested and (b) such sample(s) are retained for xxx months. This document cannot be reproduced except in full, without prior approval of the company.

Test item particulars:

Cross-sectional areas of conductors: **10 – 95 mm²**

Conductor material(s): **Al / Cu**

Shape of conductors.....: **Round**

Type of the conductor: **Stranded**

Stranded conductors, if known:

- hardness.....: -

- type of plating.....: -

- number and arrangement of strands.....: -

- type of impregnation, water blocking, etc.....: -

In case insulation piercing connectors:

- material and thickness of insulation ...: -

- type of insulation and installation temperature.....: -

Connector class: **A**

Tool for compressions.....: -

Compression jaws.....: -

Number of compressions.....: -

Protection grease: **SR 1**

Diameter of screws: **12 mm**

Nominal tightening torque of screws.....: **Shear-head bolt**


Preparation of contact surfaces.....: **Brushed conductors**

Test case verdicts

Test case does not apply to the test object.: **N(.A.)**

Test item does meet the requirement.....: **P(ass)**

Test item does not meet the requirement....: **F(ail)**




IEC 61238-1:2003

Clause	Requirement - Test	Result - Remark	Verdict
6	ELECTRICAL TESTS		
6.1	Installations		
	conductors of same cross-sectional area, taken from the same continuous core		P
	test shall be made with six specimens		P
	connectors assembled in accordance with manufacturers instruction		P
	insulation removed before assembly		P
	ambient temperature between 15 °C and 30 °C		P
	Insulation piercing connector (IPC):		
	- insulation retained under and at least 100 mm outside the connector		N
	- reference conductor with insulation including test loop		N
	- when assembling IPC, temperature 23±3°C		N
6.1.1	Through connectors and terminal lugs		
	test loop according to figure 1.....	Figure 1B	P
	Terminal lugs:		
	- palm connected direct to palm		P
	- palms bolted to linking bars		N
	- palms bolted to plant terminal etc., agreement between parties		N
	Linking bars shall be, at the point of connection:		
	- same material as palm		N
	- same dimensions and thickness as palm		N
6.1.2	Branch connectors		
	when branch conductor immediately below, above or same as main, treated as through connector		N
	test loop according to figure 2		N
6.3	Heat cycle test		
6.3.1	First heat cycle		
	heating current (A)	359 A	P
	temperature of reference conductor (°C).....	140°C	P
	temperature of median connector (°C).....	94°C	P
	temperature of linking bars (°C).....		N
	When tests of IPCs, maximum conductor temperature in normal use (°C).....		N
6.3.2	Second heat cycle		

IEC 61238-1:2003			
Clause	Requirement - Test	Result - Remark	Verdict
	durations of heating (t_1) and cooling (t_2) periods (min):	t_1 36 min; t_2 13 min	P
6.3.3	Subsequent heat cycles		
	a total of 1000 heat cycles		P
	Maximum connectors temperature during heat cycles ($^{\circ}\text{C}$).....:	99 $^{\circ}\text{C}$	P
	Measurements at following cycles:		
	Class A connectors:		
	$\Delta U_1 \rightarrow$ before the first heat cycle $\Delta U_2 \rightarrow$ after the $200^{\text{th}} \pm 10^{\text{th}}$ heat cycles however before short circuits $\Delta U_3 \rightarrow$ after the short circuits $\Delta U_4 \rightarrow$ after the $250^{\text{th}} \pm 10^{\text{th}}$ heat cycle then every 75 cycles. (In total 14 measurements)	Measuring results are in annex 1, Summary table of the test results.	P
	measuring current (A).....:	179 A	P
	Class B connectors:		
	$\Delta U_1 \rightarrow$ before the first heat cycle $\Delta U_2 \rightarrow$ after the $250^{\text{th}} \pm 10^{\text{th}}$ heat cycle then every 75 cycles. (In total 12 measurements)		N
	measuring current (A).....:		N
6.3.4	Short-circuit tests (for class A connectors only)		
	six short-circuits applied after 200^{th} cycles		P
	temperature raises from $\leq 35^{\circ}\text{C}$ to between 250°C and 270°C	Max. 276°C	P
	for IPC connectors, maximum permissible temperature of the insulation ($^{\circ}\text{C}$).....:		N
	duration of short-circuit test (s).....:	0,85 s	P
	current in short-circuit test (A).....:	Max. 13,3 kA	P
6.5	Requirements		
	Six connectors shall comply with the requirements (Table 2):		
	- initial scatter $\delta \leq 0,30$:	0,04	P
	- mean scatter $\beta \leq 0,30$:	0,17	P
	- change of resistance factor $D \leq 0,15$:	0,05	P
	- resistance factor ratio $\lambda \leq 2,0$:	1,30	P
	- connectors maximum temperature $\theta_{\text{max}} \leq \theta_{\text{ref}}$:	θ_{max} 99°C ; θ_{ref} 142°C	P

7	MECHANICAL TESTS		
7.1	Method		
	test shall be made with three additional specimens		N
	connectors assembled as for electrical test		N



IEC 61238-1:2003

Clause	Requirement - Test	Result - Remark	Verdict
	connectors for different cross-section areas, the different connectors tested individually		N
	conductors length ≥ 500 mm.....		N
	Tensile force for mechanical test (table 3):		
	- for aluminium conductors $40 \text{ N} \times A$, max 20 kN		N
	- for copper conductors $60 \text{ N} \times A$, max 20 kN		N
	load not exceed $10 \text{ N/mm}^2/\text{s}$		N
	load maintained for 1 minute		N
	no slipping shall occur during the test		N

SUMMARY TABLE OF THE TEST RESULTS		
- connector type	Screw cable lug	
- cross-sectional areas of conductor(s)	95 mm ²	
- connectors class	A	
- protection grease	SR1	
- tightening torque [Nm]	17 Nm	
- tool for compressing	-	
- jaws and number of compressions	-	
- conductors in heat cycle tests	Al 95 mm ²	
- load current [dc]	359 A	
- measuring current [dc]	179 A	
- durations of heating (t ₁) and cooling (t ₂) periods [min]	t ₁ 36 min; t ₂ 13 min	
- short circuit test		
- short circuit current [kA]	Max. 13,3 kA	
- time [s]	0,85 s	
- temperature [°C]	Max. 276 °C	


Resistance values:

Cycle no.	Sample 1 [mΩ]	Sample 2 [mΩ]	Sample 3 [mΩ]	Sample 4 [mΩ]	Sample 5 [mΩ]	Sample 6 [mΩ]	Ref. conductor [mΩ]
0	0,0650	0,0656	0,0648	0,0648	0,0650	0,0656	0,1562
200 th	0,0651	0,0656	0,0657	0,0651	0,0642	0,0658	0,1550
201 st	0,0628	0,0646	0,0631	0,0624	0,0637	0,0644	0,1507
250 th	0,0651	0,0665	0,0677	0,0652	0,0658	0,0679	0,1557
325 th	0,0651	0,0658	0,0680	0,0651	0,0657	0,0680	0,1560
400 th	0,0650	0,0657	0,0679	0,0649	0,0657	0,0680	0,1556
475 th	0,0650	0,0656	0,0680	0,0648	0,0657	0,0680	0,1556
550 th	0,0649	0,0656	0,0678	0,0645	0,0656	0,0679	0,1554
625 th	0,0650	0,0657	0,0680	0,0646	0,0658	0,0681	0,1556
700 th	0,0651	0,0659	0,0680	0,0646	0,0658	0,0681	0,1557
775 th	0,0650	0,0658	0,0679	0,0645	0,0657	0,0680	0,1555
850 th	0,0650	0,0657	0,0678	0,0645	0,0657	0,0680	0,1552
925 th	0,0650	0,0657	0,0679	0,0646	0,0658	0,0681	0,1554
1000 th	0,0651	0,0657	0,0679	0,0646	0,0658	0,0681	0,1553

Length of the measuring points

Sample 1 [mm]	Sample 2 [mm]	Sample 3 [mm]	Sample 4 [mm]	Sample 5 [mm]	Sample 6 [mm]	Ref. conductor [mm]
l _a 152 l _b 1	l _a 152 l _b 1	l _a 151 l _b 1	l _a 151 l _b 1	l _a 152 l _b 1	l _a 152 l _b 1	450









Laboratory Report

No.: 3332S

Revision: A

Page: 1/5

Date of Test: 25.11.2015 –
23.1.2016

Test object:

Bird protector SP67.3.

Purpose of the test and relevant standards:

Test for markings.

Climatic ageing test according to EN 50397-2:2009 clause 7.10.2.2 and IEC 60068-2-5:2010 procedure B.

Conclusion:

The bird protector passed the test.



Picture 1: Bird protector SP67.3

Date of Report: 25.1.2016

Ola Forsström
Tested by: Ola Forsström

Janne Lappalainen
Approved by: Janne Lappalainen

ENSTO
UTILITY NETWORKS
LABORATORY

Ordered by: K. Gajewski
Distribution: KGa, PPu, SOr

ENSTO



Laboratory Report

No.: 3332S

Revision: A

Page: 2/5

1. Test objects

Bird protector:

Type:

SP67.3 (PMR3007)

Manufacturer:

Ensto Finland Oy

Batch number:

11/2015

No of pcs:

2

2. Testing procedure


For the purpose of this test only the part of the bird protector containing markings was used.

The test was carried out in a solar environmental chamber, where an irradiance of $1090 \text{ W/m}^2 \pm 10 \%$ with the spectral distribution given in Table 1 was provided over an irradiation measurement plane of $750 \text{ mm} \times 750 \text{ mm}$. This value includes any radiation reflected from the test chamber. The radiation was produced with one 4000 W Metal Halide Global lamp with a replacement interval of 1120 h. The lamp is pre-selected by the supplier to ensure compliance with the standard requirement regarding spectral distribution.

The test consists of 56 daily cycles (8 weeks). Each cycle consist of 20 h irradiation and 4 h darkness, as shown in Picture 3. During the irradiation period the temperature within the test chamber rises at approximately $1 \text{ }^\circ\text{C/min}$ to $55 \pm 2 \text{ }^\circ\text{C}$, and is thereafter maintained at this level. During the darkness period the temperatures falls at approximately $1 \text{ }^\circ\text{C/min}$ to $25 \pm 2 \text{ }^\circ\text{C}$, and is thereafter maintained at this level. Two RTDs (Pt100) placed 20 mm below the measurement plane at half the distance between the specimen and both side walls of the test chamber are used to monitor and control the temperature. Picture 4 shows measured temperature and relative humidity values for one daily cycle.

Spectral region	Ultra-violet B	Ultra-violet A	Visible	Infra-red	Total radiation
Bandwidth	300 nm – 320 nm	320 nm – 400 nm	400 nm – 800 nm	800 nm – 2450 nm	300 nm – 2450 nm
Irradiance, measured	2,8 W/m ²	68,2 W/m ²	563,8 W/m ²	455,2 W/m ²	1090 W/m ²
Irradiance, std. requirement	4,06 W/m ²	70,5 W/m ²	604,2 W/m ²	411,2 W/m ²	1090 W/m ²

Table 1: Spectral energy distribution




Picture 2: Measured spectral distribution of irradiation intensity

Laboratory Report

No.: 3332S


Revision: A

Page: 3/5



Picture 3: Temperature-radiation-time relationships

RH(%) Temp(°C)



Picture 4: Daily cycle plot of T and $RH\%$

Requirements

Visual inspection shall be carried out to determine that there has been no degradation of the organic parts.

The sample's identification markings shall be legible when examined with normal or corrected vision without magnification.

No deterioration of the sample shall occur which would impair the normal function of the bird protector.



Laboratory Report

No.: 3332S

Revision: A

Page: 4/5

3. Test results

No visual degradation of the bird protector was observed after the simulated solar radiation test. The sample also withstood mechanical bending and twisting by hand. The markings were legible.

Summary

The bird protector fulfilled the test requirements.

4. Pictures



Picture 5: Tested samples

Laboratory Report

No.: 3332S

Revision: A

Page: 5/5

5. Test equipment

ID	Type	Model	Purpose	Latest calibration
UV3	Climate chamber	SEC 1100	Climate testing	15.09.2014

6. Test Id

3543

7. Revision history

A





Our ref.: 59725

Certificate FILab/16001

The Testing facility

Ensto Finland Oy Ensto Utility Networks

Ensio Miettisen katu 2
FI-06150 PORVOO
Finland

has been assessed and found out to meet the relevant requirements of

EN ISO/IEC 17025:2005

SGS Fimko has authorized the testing facility to test products as Customer Testing Facility (CTF) stage 2 and 3 in order to utilize the test results for FI-certifications issued by SGS Fimko Ltd according to the following standards (limitations apply):

IEC 61238-1 (ed.2)
EN 50397-1:2006 (table 2, 1.2)
EN 50397-2:2009
HD 605:2008 (item 3.2.2.2)
EN 50483-1, -2, -3, -4, -5, -6:2009
IEC 61284 (ed.2)

This certificate is valid three years from the date of issue provided that the testing facility fulfils the criteria for maintaining recognition for the relevant CTF stage and as defined in the applicable IECEE Operational Document.

Date of issue: 10th December 2015

Authorised by


Mika Richardt

SGS Fimko Ltd

Särkiniementie 3, FI-00210 Helsinki, Finland

Phone +358 (0)9 6963 61 - Fax +358 (0)9 692 5474 www.sgsfimko.com

Page 1 of 1





AKKREDITOINTITODISTUS

ACCREDITATION CERTIFICATE

ENSTO FINLAND OY
ENSTO UTILITY NETWORKS LABORATORY
PORVOO

T284

on FINAS-akkreditointipalvelun akkreditoima testauslaboratorio T284.
Akkreditointipäätös on voimassa 25.11.2018 asti.
Tiedot akkreditoinnin pätevyysalueesta ja voimassaolosta on esitetty
verkkosivuilla www.finas.fi.

is testing laboratory No. T284 accredited by FINAS Finnish Accreditation Service.
The accreditation decision is valid until 25.11.2018.
Information about the scope and the current status of the accreditation is available
on the web page www.finas.fi.

Toimielin täyttää seuraavan standardin vaatimukset:
The above body conforms to the requirements of the following standard:

SFS-EN ISO/IEC 17025:2005

Espoo 25.11.2014


Leena Tikkanen


Mika Penttinen



ENSTO

SO256.2

Tension clamp

Code	SO256.2
GTIN	6438100303839
ENumber	
Name	Tension clamp PAS/BLL-T 95-157 mm ² AlMgSi hoist adapter
Description	Tension clamp for covered conductors (PAS/BLL AlMgSi). The insulation piercing contact part has silicone seal which prevents the moisture getting into the conductor. Clamps are equipped with an adapter for hoist hook.



Technical specification

Dimensions

Weight:	2.79 kg
Conductor diameter:	16.1 ... 22.3 mm

Features

For conductor size:	PAS / BLL 95-157 mm ² AlMgSi
---------------------	---

Mechanical

SMFL:	25 kN
Tightening torque:	40 Nm
SMDL:	22 kN

Certificates

Standards:	EN 50397-2
------------	------------

Specification

Construction:



Construction:

Component	Material
Body	Corrosion resistant aluminium alloy
Bolts	Hot-dip galvanised steel M10
Bail	Stainless steel
Plastic parts	Frost, heat and UV-radiation resistant plastic
Hoist adapter	Hot-dip galvanised steel

Installation:

The clamp is opened and the conductor wire is inserted between the wedges. The locking connector is tightened. Tightening torque 40 Nm. The clamp is closed and strained.

Markings:**Markings:****ENSTO**

SO256.2

95-157 mm²

40 Nm


week/year of manufacture

Packaging**Default package**

Unit:	PCS
Size:	3
Length:	1130 mm
Width:	150 mm
Height:	120 mm
Weight (net):	8.37 kg
Weight (brt):	8.43 kg
Volume:	0.0203


Pallet package

Unit:	PCS
Size:	90
Length:	1200 mm
Width:	800 mm
Height:	860 mm
Weight (net):	251.1 kg



Weight (brt):	272 kg
Volume:	0.8256






ENSTO

SP67.3

Bird protector set

Code	SP67.3
GTIN	6438100322946
ENumber	
Name	Bird protector set
	For tension clamp SO256, set includes covers for three phases.
Description	SP67.3 is a bird protection set for tension clamp SO256. The products are manufactured of weather and UV-resistance thermoplastic material. The bird protectors prevent failures created by birds or other animals. Set includes covers for three phases.



Technical specification

Ratings

ETIM class: EC002976

Specification

Use: SP67.3 is a bird protection set for tension clamp SO256. The products are manufactured of weather and UV-resistance thermoplastic material. The bird protectors prevent failures created by birds or other animals

Construction:

Construction:

The SP67.3 delivery includes

Bird protector units	3 pcs
Cable tie	12 pcs

Installation:

The SP 67.3 bird protector is mounted on SO256 tension clamp. Hole for the jumper cable is cut with a knife.

Tools required:


Knife for jumper cable hole.

Markings:

Ensto

Standard:

EN 60068-2-5



ETIM

ETIM

Insulated neck diameter: 81 mm

Packaging

Default package

Unit: PCS

Size: 1



ЦЕНОВО ПРЕДЛОЖЕНИЕ

От: „Филкаб“ АД (наименование на участника)

По обществена поръчка за възлагане чрез събиране на оферти с обява

№ 368-EP-17-MP-D-3 с предмет: Доставка на арматура за изолирана въздушна мрежа Ср.Н.

№	НАИМЕНОВАНИЕ	Мярка	Прогнозно количество	Ед. цена лева, без вкл. ДДС	Стойност лева, без вкл. ДДС
1	Опъвателна клема за изолиран проводник за PAS 95 мм2	бр.	291	100,00	29 100,00
2	Изоляция за опъвателна клема за PAS 95 мм2	бр.	97	240,60	23 338,20
Обща стойност, в лева, без включен ДДС⁴:					52 438,20

Посочените по-горе количества са прогнозни, необвързващи за Възложителя и служат за изготвяне на ценово сравнение между участниците.

Дата. **25.08.2017**

УЧАСТНИК:
(подпис и печат)



Атанас Танчев
Изпълнителен директор
Филкаб АД

⁴ При разминаване между единичните цени, предложени от участника и общата стойност, се взема предвид единичната цена.