

I [%] of I <sub>n</sub>	Sample nr. 2.1					
	Error [%] Export					
	sin(f)=0,25 ind.		sin(f)=0,25 cap.			
R	S	T	R	S	T	
10	- 0,0		- 0,1	+ 0,3		+ 0,0
20	- 0,1		- 0,0	+ 0,2		+ 0,1
100	- 0,1		+ 0,1	+ 0,2		+ 0,1
0,5·I <sub>max</sub>	+ 0,0		+ 0,2	+ 0,1		+ 0,1
I <sub>max</sub>	+ 0,0		+ 0,2	+ 0,1		+ 0,1

I [%] of I <sub>n</sub>	Sample nr. 2.2					
	Error [%] Export					
	sin(f)=0,25 ind.		sin(f)=0,25 cap.			
R	S	T	R	S	T	
10	+ 0,4		- 0,0	- 0,1		+ 0,0
20	+ 0,4		+ 0,1	- 0,2		+ 0,0
100	+ 0,4		+ 0,1	- 0,2		+ 0,1
0,5·I <sub>max</sub>	+ 0,4		+ 0,2	- 0,3		- 0,0
I <sub>max</sub>	+ 0,5		+ 0,2	- 0,4		- 0,0

I [%] of I <sub>n</sub>	Sample nr. 3.3					
	Error [%] Import					
	sin(f)=1		sin(f)=0,5 ind.		sin(f)=0,5 cap.	
R	S	T	R	S	T	
5	+ 0,0	+ 0,0	+ 0,0			
10	+ 0,0	+ 0,0	+ 0,0	- 0,1	- 0,1	- 0,0
20	+ 0,0	+ 0,0	+ 0,0	- 0,1	- 0,0	+ 0,0
100	- 0,0	+ 0,0	+ 0,0	- 0,0	+ 0,0	+ 0,0
0,5·I <sub>max</sub>	- 0,0	+ 0,0	+ 0,0	+ 0,0	- 0,0	+ 0,0
I <sub>max</sub>	- 0,0	+ 0,0	+ 0,0	+ 0,1	+ 0,0	- 0,1

I [%] of I <sub>n</sub>	Sample nr. 3.4					
	Error [%] Import					
	sin(f)=1		sin(f)=0,5 ind.		sin(f)=0,5 cap.	
R	S	T	R	S	T	
5	+ 0,0	+ 0,0	+ 0,1			
10	+ 0,0	+ 0,0	+ 0,1	- 0,1	- 0,0	+ 0,0
20	+ 0,0	+ 0,0	+ 0,1	- 0,1	- 0,0	+ 0,0
100	+ 0,0	- 0,0	+ 0,1	- 0,0	- 0,0	+ 0,0
0,5·I <sub>max</sub>	- 0,0	+ 0,0	+ 0,1	+ 0,0	+ 0,1	- 0,1
I <sub>max</sub>	+ 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,1	- 0,0

ВЪРНО С ОРИГИНАЛО

Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД

I [%] of I <sub>n</sub>	Sample nr. 3.3 Error [%] Export								
	sin(f)=1			sin(f)=0,5 ind.			sin(f)=0,5 cap.		
	R	S	T	R	S	T	R	S	T
5	+ 0,0	+ 0,0	+ 0,0	- 0,1	- 0,1	- 0,0	+ 0,1	+ 0,1	+ 0,1
10	+ 0,0	+ 0,0	+ 0,0	- 0,0	- 0,0	- 0,0	+ 0,0	+ 0,1	+ 0,1
20	- 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	- 0,0	- 0,0	+ 0,1	+ 0,1
100	- 0,0	- 0,0	+ 0,0	+ 0,0	+ 0,0	- 0,0	- 0,0	+ 0,0	+ 0,1
0,5·Imax	+ 0,0	+ 0,0	+ 0,0	- 0,1	+ 0,0	+ 0,1	- 0,0	- 0,1	+ 0,0
Imax	+ 0,0	- 0,0	+ 0,1	+ 0,1	+ 0,0	+ 0,0	- 0,1	- 0,0	+ 0,0

I [%] of I <sub>n</sub>	Sample nr. 3.4 Error [%] Export								
	sin(f)=1			sin(f)=0,5 ind.			sin(f)=0,5 cap.		
	R	S	T	R	S	T	R	S	T
5	+ 0,0	+ 0,0	+ 0,1	- 0,1	- 0,1	+ 0,0	+ 0,1	+ 0,1	+ 0,1
10	+ 0,0	+ 0,0	+ 0,1	- 0,0	- 0,0	+ 0,0	+ 0,1	+ 0,1	+ 0,1
20	+ 0,0	+ 0,0	+ 0,1	- 0,0	- 0,0	+ 0,0	+ 0,1	+ 0,1	+ 0,1
100	- 0,0	- 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,1
0,5·Imax	+ 0,0	+ 0,1	+ 0,0	- 0,1	+ 0,0	+ 0,1	- 0,0	- 0,0	+ 0,0
Imax	+ 0,0	- 0,0	+ 0,1	+ 0,1	+ 0,0	+ 0,1	- 0,1	+ 0,0	- 0,0

I [%] of I <sub>n</sub>	Sample nr. 3.3 Error [%] Import								
	sin(f)=0,25 ind.			sin(f)=0,25 cap.					
	R	S	T	R	S	T	R	S	T
10	- 0,2	- 0,2	- 0,1	+ 0,2	+ 0,2	+ 0,2			
20	- 0,2	- 0,1	- 0,1	+ 0,2	+ 0,2	+ 0,2			
100	- 0,1	- 0,1	- 0,1	+ 0,1	+ 0,1	+ 0,1			
0,5·Imax	+ 0,0	+ 0,0	+ 0,0	- 0,1	- 0,0	+ 0,1			
Imax	+ 0,1	+ 0,0	+ 0,0	- 0,1	- 0,1	+ 0,1			

I [%] of I <sub>n</sub>	Sample nr. 3.4 Error [%] Import								
	sin(f)=0,25 ind.			sin(f)=0,25 cap.					
	R	S	T	R	S	T	R	S	T
10	- 0,2	- 0,1	- 0,1	+ 0,2	+ 0,2	+ 0,2			
20	- 0,2	- 0,2	- 0,0	+ 0,2	+ 0,2	+ 0,2			
100	- 0,1	- 0,1	+ 0,0	+ 0,1	+ 0,1	+ 0,1			
0,5·Imax	+ 0,0	+ 0,0	+ 0,1	+ 0,0	+ 0,0	+ 0,0			
Imax	+ 0,1	+ 0,1	+ 0,1	- 0,1	- 0,0	+ 0,0			

I [%] of I <sub>n</sub>	Sample nr. 3.3 Error [%] Export								
	sin(f)=0,25 ind.			sin(f)=0,25 cap.					
	R	S	T	R	S	T	R	S	T
10	+ 0,2	+ 0,2	+ 0,2	- 0,2	- 0,2	- 0,1			
20	+ 0,2	+ 0,2	+ 0,2	- 0,1	- 0,2	- 0,1			
100	+ 0,0	+ 0,0	+ 0,1	- 0,1	- 0,1	- 0,0			
0,5·Imax	- 0,1	- 0,0	+ 0,1	+ 0,0	+ 0,0	+ 0,0			

Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД

ВЪВРХ С ОРИГИНАЛ



I [%] of I <sub>n</sub>	Sample nr. 3.4						
	Error [%] Export						
	sin(f)=0,25 ind.			sin(f)=0,25 cap.			
R	S	T	R	S	T		
10	+ 0,2	+ 0,2	+ 0,2	- 0,1	- 0,1	- 0,1	
20	+ 0,2	+ 0,2	+ 0,2	- 0,1	- 0,1	- 0,1	
100	+ 0,1	+ 0,1	+ 0,1	- 0,1	- 0,1	+ 0,0	
0,5-I <sub>max</sub>	+ 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,1	
I <sub>max</sub>	+ 0,2	- 0,0	- 0,0	+ 0,1	+ 0,0	+ 0,1	

I [%] of I <sub>n</sub>	Sample nr. 5.2									
	Error [%] Import									
	sin(f)=1			sin(f)=0,5 ind.			sin(f)=0,5 cap.			
R	S	T	R	S	T	R	S	T		
5	- 0,1	+ 0,0	+ 0,1							
10	- 0,0	+ 0,0	+ 0,0	- 0,1	- 0,0	- 0,1	- 0,0	+ 0,1	+ 0,1	
20	- 0,0	+ 0,0	+ 0,0	- 0,1	- 0,0	- 0,1	+ 0,0	+ 0,1	+ 0,1	
100	+ 0,0	+ 0,0	+ 0,0	- 0,1	- 0,0	- 0,0	+ 0,0	+ 0,0	+ 0,1	
0,5-I <sub>max</sub>	- 0,0	- 0,0	+ 0,0	- 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	
I <sub>max</sub>	- 0,0	+ 0,0	+ 0,0	- 0,0	+ 0,0	+ 0,1	- 0,0	- 0,1	- 0,0	

I [%] of I <sub>n</sub>	Sample nr. 5.3									
	Error [%] Import									
	sin(f)=1			sin(f)=0,5 ind.			sin(f)=0,5 cap.			
R	S	T	R	S	T	R	S	T		
5	- 0,1	+ 0,0	+ 0,1							
10	- 0,0	+ 0,0	+ 0,1	- 0,2	- 0,0	+ 0,0	+ 0,0	+ 0,1	+ 0,1	
20	- 0,0	+ 0,0	+ 0,0	- 0,1	- 0,0	- 0,0	+ 0,0	+ 0,1	+ 0,1	
100	+ 0,0	+ 0,0	+ 0,0	- 0,1	- 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	
0,5-I <sub>max</sub>	- 0,0	+ 0,0	+ 0,0	- 0,0	+ 0,1	+ 0,0	- 0,0	- 0,0	+ 0,0	
I <sub>max</sub>	- 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,1	+ 0,1	- 0,1	- 0,1	- 0,0	

I [%] of I <sub>n</sub>	Sample nr. 5.2									
	Error [%] Export									
	sin(f)=1			sin(f)=0,5 ind.			sin(f)=0,5 cap.			
R	S	T	R	S	T	R	S	T		
5	+ 0,0	- 0,0	+ 0,0							
10	+ 0,0	+ 0,0	+ 0,0	- 0,0	- 0,1	- 0,1	+ 0,1	+ 0,1	+ 0,1	
20	+ 0,0	- 0,0	+ 0,0	- 0,0	- 0,1	- 0,1	+ 0,1	+ 0,1	+ 0,1	
100	+ 0,0	+ 0,0	+ 0,0	- 0,0	- 0,0	- 0,0	+ 0,0	+ 0,0	+ 0,1	
0,5-I <sub>max</sub>	+ 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	- 0,0	- 0,0	+ 0,0	+ 0,1	
I <sub>max</sub>	- 0,0	- 0,0	- 0,0	- 0,0	+ 0,1	+ 0,1	+ 0,0	- 0,0	- 0,0	

I [%] of I <sub>n</sub>	Sample nr. 5.3									
	Error [%] Export									
	sin(f)=1			sin(f)=0,5 ind.			sin(f)=0,5 cap.			
R	S	T	R	S	T	R	S	T		
5	+ 0,0	- 0,0	+ 0,0							
10	+ 0,0	+ 0,0	+ 0,0	- 0,0	- 0,1	- 0,0	+ 0,1	+ 0,1	+ 0,1	
20	+ 0,0	+ 0,0	+ 0,0	- 0,1	- 0,1	- 0,0	+ 0,1	+ 0,1	+ 0,1	
100	- 0,0	+ 0,0	+ 0,0	- 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,1	+ 0,1	
0,5-I <sub>max</sub>	- 0,0	+ 0,0	+ 0,1	- 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	
I <sub>max</sub>										

Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД



### Test: Starting and no-load condition

The starting and no-load condition is checked at reference conditions.

#### Results:

Sample nr. 1.2	
No-load condition with no current and a voltage of 115% of the reference voltage	✓
Registration checked at % of $I_n$	0,2 %
Registration checked at % of $I_n$ with export energy	0,2 %

Sample nr. 1.9	
No-load condition with no current and a voltage of 115% of the reference voltage	✓
Registration checked at % of $I_n$	0,2 %
Registration checked at % of $I_n$ with export energy	0,2 %

The meter is functional within 5 s after the rated voltage is applied to the meter terminals:

yes

Sample nr. 2.1	
No-load condition with no current and a voltage of 115% of the reference voltage	✓
Registration checked at % of $I_n$	0,2 %
Registration checked at % of $I_n$ with export energy	0,2 %

Sample nr. 2.2	
No-load condition with no current and a voltage of 115% of the reference voltage	✓
Registration checked at % of $I_n$	0,2 %
Registration checked at % of $I_n$ with export energy	0,2 %

ВЪРНО С ОРИГИНАЛ

Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД





Sample nr.3.3

No-load condition with no current and a voltage of 115% of the reference voltage	✓
Registration checked at % of $I_n$	0,2 %
Registration checked at % of $I_n$ with export energy	0,2 %

Sample nr. 3.4

No-load condition with no current and a voltage of 115% of the reference voltage	✓
Registration checked at % of $I_n$	0,2 %
Registration checked at % of $I_n$ with export energy	0,2 %

The meter is functional within 5 s after the rated voltage is applied to the meter terminals:

yes

Sample nr.5.2

No-load condition with no current and a voltage of 115% of the reference voltage	✓
Registration checked at % of $I_n$	0,2 %
Registration checked at % of $I_n$ with export energy	0,2 %

Sample nr. 5.3

No-load condition with no current and a voltage of 115% of the reference voltage	✓
Registration checked at % of $I_n$	0,2 %
Registration checked at % of $I_n$ with export energy	0,2 %

The meter is functional within 5 s after the rated voltage is applied to the meter terminals:

yes



Информацията е заличена сълг. чл. 45 и чл. 59, ал. 1 от ЗЗЛД





Report number NMI-1901209-04  
Annex 3  
Page 13 of 23

**Test: Meter constant**

The meter constant is checked with the value stated on the nameplate.

Results: The test is performed with:                      Sample nr. 1.2  
    Sample nr. 1.9

The meter constant as stated on the nameplate complies with the measured values of the test output.

ВЪВЪД С ОРИГИНАЛ

Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД

**Test: Variation of the error due to variation of the voltage**

The variation of the error is measured due to variation of the voltage at nominal current and different values of the power factor.

**Results:**

Sample nr. 1.8 3x58/100V		
	$I_n$	
percentage of $U_{ref}$	power factor	variation [%]
115	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
110	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
90	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
80	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
20	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
<20	1	
	0,5 ind.	no registration
	0,5 cap.	

Sample nr. 1.9 3x58/100V		
	$I_n$	
percentage of $U_{ref}$	power factor	variation [%]
115	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
110	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
90	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	- 0,0
80	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	- 0,0
20	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	- 0,0
<20	1	
	0,5 ind.	no registration

Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД

БЪЛГАРСКА ОДИНАЖДА





Sample nr. 1.8 3x240/415V		
	$I_n$	
percentage of $U_{ref}$	power factor	variation [%]
115	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
110	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
90	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
80	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
5	1	- 0,1
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
<5	1	
	0,5 ind.	
	0,5 cap.	no registration

Sample nr. 1.9 3x240/415V		
	$I_n$	
percentage of $U_{ref}$	power factor	variation [%]
115	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
110	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
90	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
80	1	+ 0,0
	0,5 ind.	+ 0,0
	0,5 cap.	+ 0,0
5	1	- 0,1
	0,5 ind.	+ 0,0
	0,5 cap.	- 0,0
<5	1	
	0,5 ind.	
	0,5 cap.	no registration

Definition: Variation =  $(Error at percentage of U_{ref}) - (Error at reference conditions)$   
Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД



**Test: Variation of the error due to variation of the frequency**

The variation of the error is measured at the stated changes of the frequency at different values of the current and the power factor.

**Results:**

Sample nr. 1.2		
U <sub>ref</sub>	Variation at frequency	
	49 Hz	51 Hz
I=0,1I <sub>n</sub> , sin(f)=1	- 0,0	- 0,0
I=0,5I <sub>max</sub> , sin(f)=1	- 0,0	- 0,0
I=0,5I <sub>max</sub> , sin(f)=0,5 ind.	- 0,0	- 0,0
I=0,5I <sub>max</sub> , sin(f)=0,5 cap.	- 0,0	- 0,0

Sample nr. 1.9		
U <sub>ref</sub>	Variation at frequency	
	49 Hz	51 Hz
I=0,1I <sub>n</sub> , sin(f)=1	- 0,0	- 0,0
I=0,5I <sub>max</sub> , sin(f)=1	- 0,0	- 0,0
I=0,5I <sub>max</sub> , sin(f)=0,5 ind.	- 0,0	- 0,0
I=0,5I <sub>max</sub> , sin(f)=0,5 cap.	- 0,0	+ 0,0

Sample nr. 1.2		
U <sub>ref</sub>	Variation at frequency	
	58,8 Hz	61,2 Hz
I=0,1I <sub>n</sub> , sin(f)=1	- 0,0	- 0,0
I=0,5I <sub>max</sub> , sin(f)=1	- 0,0	- 0,0
I=0,5I <sub>max</sub> , sin(f)=0,5 ind.	+ 0,0	- 0,0
I=0,5I <sub>max</sub> , sin(f)=0,5 cap.	- 0,0	+ 0,0

Sample nr. 1.9		
U <sub>ref</sub>	Variation at frequency	
	58,8 Hz	61,2 Hz
I=0,1I <sub>n</sub> , sin(f)=1	+ 0,0	+ 0,0
I=0,5I <sub>max</sub> , sin(f)=1	+ 0,0	+ 0,0
I=0,5I <sub>max</sub> , sin(f)=0,5 ind.	+ 0,0	+ 0,0
I=0,5I <sub>max</sub> , sin(f)=0,5 cap.	+ 0,0	+ 0,0

**Definition:** Variation = (Error at stated frequency) - (Error at reference conditions)

Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗПД





**Test: Operation of accessories**

The influence of the operation of accessories is determined at 1% of the nominal current.

**Results:**

Sample nr. 1.2	
error without operation of accessories [%]	+ 0,03
error with communication via the optical port [%]	+ 0,00
variation [%]	- 0,03

**Definition:** Variation = (Error with operation of accessories) - (Error without operation of accessories)

ВЪРХО С ОРИГИНАЛА

Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД

115

САНКТ ПЕТЕРБУРГ  
САНКТ-ПЕТЕРБУРГСКИЙ ГОСУДАРСТВЕННЫЙ УНИВЕРСИТЕТ  
САНКТ-ПЕТЕРБУРГСКИЙ ГОСУДАРСТВЕННЫЙ УНИВЕРСИТЕТ

**Test: Variation of the error due to variation of the temperature**

The variation of the error is determined due to variation of the temperature.

The error of indication is measured at a reference temperature of + $^{\circ}$ C and at the stated temperatures.

The shift of the error due to the shift of temperature is stated in the following tables.

$U_{ref}$	Variation at temperature							Max. temperature coëfficiënt %/K
	-40°C	-25°C	-10°C	5°C	40°C	55°C	70°C	
$I=0,1I_n, \sin(f)=1$	- 0,0	- 0,0	- 0,0	- 0,0	+ 0,0	+ 0,0	+ 0,1	0,001
$I=0,2I_n, \sin(f)=0,5 \text{ ind.}$	+ 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	- 0,0	- 0,0	0,001
$I=0,2I_n, \sin(f)=0,5 \text{ cap.}$	- 0,1	- 0,1	- 0,1	- 0,0	+ 0,1	+ 0,1	+ 0,1	0,006
$I=I_n, \sin(f)=1$	- 0,1	- 0,0	- 0,0	- 0,0	+ 0,0	+ 0,0	+ 0,0	0,001
$I=I_n, \sin(f)=0,5 \text{ ind.}$	+ 0,0	+ 0,0	+ 0,0	+ 0,0	- 0,0	- 0,0	- 0,0	0,001
$I=I_n, \sin(f)=0,5 \text{ cap.}$	- 0,1	- 0,1	- 0,1	- 0,0	+ 0,0	+ 0,1	+ 0,1	0,003
$I=I_{max}, \sin(f)=1$	- 0,0	- 0,0	- 0,0	- 0,0	+ 0,0	+ 0,0	+ 0,0	0,001
$I=I_{max}, \sin(f)=0,5 \text{ ind.}$	+ 0,0	+ 0,0	+ 0,0	+ 0,0	+ 0,0	- 0,0	- 0,0	0,001
$I=I_{max}, \sin(f)=0,5 \text{ cap.}$	- 0,1	- 0,1	- 0,1	- 0,1	+ 0,0	+ 0,1	+ 0,1	0,003

$U_{ref}$	Variation at temperature							Max. temperature coëfficiënt %/K
	-40°C	-25°C	-10°C	5°C	40°C	55°C	70°C	
$I=0,1I_n, \sin(f)=1$	- 0,2	- 0,2	- 0,1	- 0,0	+ 0,1	+ 0,1	+ 0,1	0,005
$I=0,2I_n, \sin(f)=0,5 \text{ ind.}$	- 0,2	- 0,1	- 0,0	- 0,0	+ 0,0	+ 0,1	+ 0,1	0,005
$I=0,2I_n, \sin(f)=0,5 \text{ cap.}$	- 0,3	- 0,2	- 0,1	- 0,1	+ 0,1	+ 0,1	+ 0,2	0,007
$I=I_n, \sin(f)=1$	- 0,2	- 0,2	- 0,1	- 0,0	+ 0,0	+ 0,1	+ 0,1	0,006
$I=I_n, \sin(f)=0,5 \text{ ind.}$	- 0,2	- 0,1	- 0,0	- 0,0	+ 0,0	+ 0,1	+ 0,1	0,005
$I=I_n, \sin(f)=0,5 \text{ cap.}$	- 0,3	- 0,2	- 0,1	- 0,1	+ 0,1	+ 0,1	+ 0,2	0,007
$I=I_{max}, \sin(f)=1$	- 0,2	- 0,2	- 0,1	- 0,1	+ 0,0	+ 0,1	+ 0,1	0,006
$I=I_{max}, \sin(f)=0,5 \text{ ind.}$	- 0,2	- 0,1	- 0,0	- 0,0	+ 0,0	+ 0,1	+ 0,1	0,005
$I=I_{max}, \sin(f)=0,5 \text{ cap.}$	- 0,3	- 0,2	- 0,1	- 0,1	+ 0,1	+ 0,1	+ 0,2	0,007

**Definition:** Variation = (Error at specified temperature) - (Average error at +23°C)

**Remark:** Instead of the prescribed 20 K range (see par. 8.3, remark 7, of the IEC 62053-24), the above mentioned temperatures are used.



Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД

116



**Test: Variation of the error due to harmonics**

The watthourmeter is tested with harmonics. The following tests are performed:  
- harmonic components in the current and voltage circuits;

**Results:**

harmonic components in the current and voltage circuits:

$U_{ref}, I=0,5I_{max}, \sin(f)=1$		
$U_5 = 10\%, I_5 = 40\%, \sin(f_5)=1$	Sample nr. 1.2	Sample nr. 1.9
error without harmonics [%]	+ 0,00	+ 0,00
error with harmonics [%]	+ 1,41	+ 1,42
variation [%]	+ 1,41	+ 1,42

$U_{ref}, I=0,5I_{max}, \sin(f)=1$		
$U_5 = 10\%, I_5 = 40\%, \sin(f_5)=0$	Sample nr. 1.2	Sample nr. 1.9
error without harmonics [%]	+ 0,00	+ 0,00
error with harmonics [%]	- 0,01	- 0,01
variation [%]	- 0,01	- 0,01

**Definition:** Variation = (Error with harmonics) - (Error without harmonics)

ВЪВРНО С ОРИГИНАЛ

Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД

51 4 197

888 LANG LTD.



**Test: Continuous magnetic induction of external origin**

The influence of a continuous magnetic field on the registration of the watthourmeter is investigated. The continuous magnetic induction is obtained by using the electromagnet according to annex B of the , energized with a DC current.

A magneto-motive force of 1000 At (ampere-turns) is applied.

The test is performed with sample nr. 1.1 and 5.2.

**Results:** The influence due to the continuous magnetic field was negligible.

The meter was functioning correctly when applying the magnetic field.

ВЪВРНО С ОРИГИНАЛ

ВЪВРНО С ОРИГИНАЛ

Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД



**Test: Variation of the error due to a magnetic induction of external origin (0,5 mT)**

The influence of an external magnetic field on the registration of the meter is investigated, with a field strength of 0,5 mT.

An external magnetic field is made with the help of a round coil with a diameter of 1 meter. The meter is placed into the middle of the coil.

The measurements are performed with a variable phase shift between the current that caused the magnetic field and the measuring circuit voltage of the meter.

The phase shift is adjusted between 0° and 360°. For each measurement the coil and the meter are placed in several positions.

**Results:**

Sample nr. 1.2	
$U=U_{ref}$ , $I=I_n$ and $\sin(f)=1$	
Variation [%]	< 0,05

Sample nr. 5.2	
$U=U_{ref}$ , $I=I_n$ and $\sin(f)=1$	
Variation [%]	< 0,10

**Definition:** Variation = (Error with an external magnetic field) - (Error at reference conditions)

**Remark:** The uncertainty in the generated magnetic field is 1%.



Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗПД



**Test: Power consumption**

The power consumption of the voltage circuit and the current circuit is measured at reference conditions and at the stated current.

**Results:**

	Sample nr. 1.1	Sample nr. 1.2
power consumption of the voltage circuit	1,2 VA and 0,5 W	1,2 VA and 0,5 W
power consumption of the current circuit with nominal current	0,00 VA	0,00 VA

ВЪРНО С ОРИГИНАЛ

Информацията е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД

**Test: Variation of the error due to self-heating**

The influence of self-heating of the watthourmeter is determined by difference occurring in the error at measuring directly after switching-in of the maximum current with respect to a second measurement at least one hour after switching-in of the current and after thermal stability is reached.

During the test cables are used with an area of 7 square mm.

time [min]	Sample nr. 3.3			Sample nr. 3.4		
	sin(f)=1	sin(f)=0,5 ind.	sin(f)=0,5 cap.	sin(f)=1	sin(f)=0,5 ind.	sin(f)=0,5 cap.
0	+ 0,00	+ 0,05	- 0,04	+ 0,02	+ 0,05	- 0,02
5	+ 0,00	+ 0,05	- 0,05	+ 0,01	+ 0,05	- 0,03
10	+ 0,00	+ 0,06	- 0,05	+ 0,01	+ 0,06	- 0,03
15	+ 0,00	+ 0,05	- 0,05	+ 0,01	+ 0,06	- 0,02
30	+ 0,00	+ 0,05	- 0,04	+ 0,01	+ 0,06	- 0,01
45	+ 0,00	+ 0,05	- 0,05	+ 0,01	+ 0,06	- 0,02
60	+ 0,00	+ 0,05	- 0,05	+ 0,02	+ 0,06	- 0,02
90	+ 0,00	+ 0,05	- 0,04	+ 0,01	+ 0,05	+ 0,00
120	+ 0,00	+ 0,05	- 0,04	+ 0,02	+ 0,06	+ 0,00
Variation [%]	+ 0,00	+ 0,00	+ 0,00	+ 0,00	+ 0,01	+ 0,02

**Definition:** Variation = (Error after thermal stability) - (Error at the start)

**Remark:** Before the measurements were started, the voltage was connected for at least 2 hours.



1	2	3	4	5	6	7	8
1	2	3	4	5	6	7	8
1	2	3	4	5	6	7	8
1	2	3	4	5	6	7	8
1	2	3	4	5	6	7	8
1	2	3	4	5	6	7	8
1	2	3	4	5	6	7	8
1	2	3	4	5	6	7	8

SEARCHED & INDEXED



N