

Информацията по-долу е заличена съгл. чл. 45 и чл. 59, ал. 1 от ЗЗЛД, във връзка с чл. 36а, ал. 3 от ЗОП.



Similar to the illustration

grid | power v L

Series OPzS/power.bloc OPzS

Vented lead-acid battery

grid | power v L Series OPzS

Typical applications:

- Telecommunications
 - Mobile phone stations
 - BTS-stations
 - Off-grid/on-grid solutions
- Power Supply
- Security lighting

Your benefits:

- Very high expected service life – due to optimized low-antimony selenium alloy
- Excellent cycle stability – due to tubular plate design
- Maximum compatibility – design according to DIN 40736-1
- Higher short-circuit safety even during the installation – based on HOPPECKE system connectors
- Extremely extended water refill intervals up to maintenance-free – optional use of AquaGen® recombination system minimizes emission of gas and aerosols¹


grid | power v L Series power.bloc OPzS

Typical applications:


- Telecommunications
 - Mobile phone stations
 - BTS-stations
 - Off-grid/on-grid solutions
- Power Supply systems
- Security lighting

Your benefits:

- High expected service life – due to optimized low-antimony selenium alloy
- Excellent cycle stability – due to tubular plate design
- Maximum compatibility – dimensions according to DIN 40737-3
- Easy assembly and installation – battery lid with integral handle
- Higher short-circuit safety even during the installation – based on HOPPECKE system connectors
- Extremely extended water refill intervals up to maintenance-free – optional use of AquaGen® recombination system minimizes emission of gas and aerosols¹



¹ Similar to sealed lead-acid batteries



Capacities dimensions and weights

Series OPzS	DIN Type	C ₁₀ /1.80 V Ah	C ₅ /1.77 V Ah	C ₃ /1.75 V Ah	C ₁ /1.67 V Ah	max.* Weight kg	Weight electrolyte kg (1.24 kg/l)	max.* Length L mm	max.* Width W mm	max.* Height H mm	Fig.
grid power vl 2-215	4 OPzS 200	213	182	161	118	17.3	4.5	105	208	420	A
grid power vl 2-270	5 OPzS 250	266	227	201	147	21.0	5.6	126	208	420	A
grid power vl 2-325	6 OPzS 300	320	273	241	177	24.9	6.7	147	208	420	A
grid power vl 2-390	5 OPzS 350	390	345	303	217	29.3	8.5	126	208	535	A
grid power vl 2-470	6 OPzS 420	468	414	363	261	34.4	10.1	147	208	535	A
grid power vl 2-550	7 OPzS 490	546	483	426	304	39.5	11.7	168	208	535	A
grid power vl 2-690	6 OPzS 600	686	590	510	353	46.1	13.3	147	208	710	A
grid power vl 2-805	7 OPzS 700	801	691	596	411	59.1	16.7	215	193	710	B
grid power vl 2-920	8 OPzS 800	915	790	681	470	63.1	17.3	215	193	710	B
grid power vl 2-1035	9 OPzS 900	1026	887	767	529	72.4	20.5	215	235	710	B
grid power vl 2-1150	10 OPzS 1000	1140	985	852	588	76.4	21.1	215	235	710	B
grid power vl 2-1265	11 OPzS 1100	1256	1086	938	647	86.6	25.2	215	277	710	B
grid power vl 2-1380	12 OPzS 1200	1370	1185	1023	706	90.6	25.8	215	277	710	B
grid power vl 2-1610	12 OPzS 1500	1610	1400	1197	784	110.4	32.7	215	277	855	B
grid power vl 2-1880	14 OPzS 1750	1881	1632	1397	914	142.3	46.2	215	400	815	C
grid power vl 2-2015	15 OPzS 1875	2016	1748	1496	980	146.6	46.7	215	400	815	C
grid power vl 2-2150	16 OPzS 2000	2150	1865	1596	1045	150.9	45.9	215	400	815	C
grid power vl 2-2420	18 OPzS 2250	2412	2097	1796	1176	179.1	56.4	215	490	815	D
grid power vl 2-2555	19 OPzS 2375	2546	2213	1895	1242	182.9	55.6	215	490	815	D
grid power vl 2-2690	20 OPzS 2500	2680	2330	1995	1307	187.3	55.7	215	490	815	D
grid power vl 2-2960	22 OPzS 2750	2952	2562	2195	1437	212.5	67.0	215	580	815	D
grid power vl 2-3095	23 OPzS 2875	3086	2678	2294	1503	216.8	65.9	215	580	815	D
grid power vl 2-3230	24 OPzS 3000	3220	2795	2394	1568	221.2	66.4	215	580	815	D
grid power vl 2-3500	26 OPzS 3250	3488	3028	2594	1699	229.6	65.4	215	580	815	D

C₁₀, C₅, C₃ and C₁ = Capacity at 10 h, 5 h, 3 h and 1 h discharge


* according to DIN 40736-1 data to be understood as maximum values

Series power.bloc OPzS	DIN Type	C ₁₀ /1.80 V Ah	C ₅ /1.77 V Ah	C ₃ /1.75 V Ah	C ₁ /1.67 V Ah	max.* Weight kg	Weight electrolyte kg (1.24 kg/l)	max.* Length L mm	max.* Width W mm	max.* Height H mm	Fig.
grid power vl 12-50	12V 1 power.bloc OPzS 50	50	44	39	28	37.0	15.0	272	205	383	A
grid power vl 12-100	12V 2 power.bloc OPzS 100	101	88	78	57	48.0	13.0	272	205	383	A
grid power vl 12-150	12V 3 power.bloc OPzS 150	151	132	117	85	67.0	18.0	380	205	383	A
grid power vl 6-200	6V 4 power.bloc OPzS 200	202	176	155	114	47.0	13.0	272	205	383	B
grid power vl 6-250	6V 5 power.bloc OPzS 250	252	220	194	142	60.0	20.0	380	205	383	B
grid power vl 6-300	6V 6 power.bloc OPzS 300	302	264	233	171	67.0	18.0	380	205	383	B

C₁₀, C₅, C₃ and C₁ = Capacity at 10 h, 5 h, 3 h and 1 h discharge


* according to DIN 40737-3 data to be understood as maximum values

Fig. A Series OPzS




grid | power vl 2-215 -
grid | power vl 2-690

Fig. B Series OPzS




grid | power vl 2-805 -
grid | power vl 2-1610

Fig. C Series OPzS




grid | power vl 2-1880 -
grid | power vl 2-2150

Fig. D Series OPzS




grid | power vl 2-2420 -
grid | power vl 2-3500

Fig. A Series power.bloc OPzS



grid | power vl 12-50 -
grid | power vl 12-150

Fig. B Series power.bloc OPzS



grid | power vl 6-200 -
grid | power vl 6-300

Design life: up to 20 years

Optimal environmental compatibility – closed loop for recovery of materials in an accredited recycling system

Design life: up to 18 years

Optimal environmental compatibility – closed loop for recovery of materials in an accredited recycling system

HOPPECKE Batterien GmbH & Co. KG
Bontkirchener Str. 1
D - 59929 Brilon
Tel: +49 (0) 2963 61-374
Fax: +49 (0) 2963 61-270
E-Mail: reservepower@hoppecke.com



Datenbasis: power_bloc OPZS Projektierungsdaten Ampere_R_INT_0802
 Discharge current in A / Entladestrom in A / Tor pasapasa m A / Courant de décharge in A
 V1.4 / 26.02.2018
 Vorlage / template: V2.1 / 04.09.2013

Batterie / Battery	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
La batterie	95,0	91,4	88,1	85,0	82,1	79,4	76,8	74,4	64,5	56,8	50,0	45,2	41,2	38,0	35,3	32,9	30,7	28,8	17,7	13,1	10,6	8,9	7,7	6,8	6,1	5,6	5,1
Grid power V.L 12-50; 1,8V/Z	190,0	183,0	176,0	170,0	164,0	159,0	154,0	149,0	129,0	114,0	100,0	90,3	82,5	76,0	70,5	65,8	61,5	57,8	35,4	26,3	21,2	17,8	15,4	13,7	12,2	11,1	10,2
Grid power V.L 12-100; 1,8V/Z	285,0	274,0	264,0	255,0	246,0	239,0	230,0	223,0	193,0	170,0	150,0	136,0	124,0	114,0	106,0	98,8	92,2	86,4	53,2	39,4	31,9	26,6	23,2	20,5	18,3	16,7	15,4
Grid power V.L 6-200; 1,8V/Z	380,0	366,0	352,0	340,0	328,0	317,8	307,8	298,0	258,0	227,0	200,0	181,0	165,0	152,0	141,0	132,0	123,0	115,0	70,8	52,5	42,5	35,5	30,9	27,4	24,4	22,3	20,5
Grid power V.L 6-250; 1,8V/Z	475,0	457,0	440,0	425,0	410,0	397,0	384,0	372,0	322,0	284,0	250,0	226,0	208,0	190,0	178,0	165,0	154,0	144,0	88,6	65,7	53,1	44,4	38,6	34,2	30,6	27,9	25,6
Grid power V.L 6-300; 1,8V/Z	570,0	548,0	528,0	510,0	492,0	476,0	461,0	447,0	387,0	341,0	300,0	271,0	247,0	228,0	212,0	198,0	184,0	173,0	106,0	78,8	63,7	53,3	46,3	41,1	36,7	33,4	30,7

Discharge current in A / Entlastestrom in A / Τοx παρπαγα σε Α / Courant de décharge in A
 V1.4 / 26.02.2018
 Voltage (Template): V2.1 (04.09.2013)

Battery / Batterie / Πρωτεύουσα / Primary	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h		
Grid power V.L. 12-150, 1.53V/Z	87.0	84.2	81.6	79.1	76.7	74.5	72.4	70.4	67.7	64.9	62.5	60.4	58.4	56.4	54.4	52.7	50.7	28.8	17.7	13.1	10.6	8.9	7.7	6.9	6.1	5.6	5.1		
Grid power V.L. 12-150, 1.53V/Z	149.0	143.0	138.0	133.0	128.0	123.0	118.0	113.0	108.0	103.0	98.0	93.0	88.1	83.1	78.1	73.2	68.3	57.6	36.4	26.3	21.2	17.8	15.2	13.3	11.7	10.2	9.2		
Grid power V.L. 12-150, 1.53V/Z	261.0	253.0	245.0	237.0	230.0	223.0	216.0	210.0	203.0	196.0	189.0	182.0	175.0	168.0	161.0	154.0	147.0	86.4	53.2	39.4	31.9	27.8	24.2	20.5	18.3	16.7	15.4		
Grid power V.L. 6-220, 1.53V/Z	346.0	337.0	328.0	318.0	309.0	300.0	291.0	281.0	274.0	266.0	258.0	250.0	242.0	234.0	226.0	218.0	210.0	114.0	69.8	51.7	43.1	37.4	32.6	28.4	24.4	20.9	20.5		
Grid power V.L. 6-250, 1.53V/Z	435.0	421.0	407.0	394.0	384.0	372.0	362.0	352.0	343.0	335.0	328.0	320.0	312.0	304.0	296.0	288.0	280.0	174.0	108.0	81.8	67.7	58.1	50.6	44.4	38.6	34.2	30.6	27.8	25.6
Grid power V.L. 6-300, 1.53V/Z	522.0	505.0	489.0	474.0	460.0	447.0	434.0	422.0	410.0	398.0	388.0	379.0	370.0	361.0	352.0	343.0	334.0	196.0	126.0	96.8	81.7	69.7	60.3	53.1	46.4	41.1	36.7	33.4	30.7

Discharge current in A / Einladestrom in A / Tok pasapaya n A / Courant de echange in A
 V1.4 / 26.02.2018
 Voltage (Template): V2.1 (04.09.2013)

Battery / Batterie / Baterija	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
Grid power V.L 12-50; 1.65V/Z	83.2	80.6	78.2	75.9	73.7	71.5	69.7	67.8	59.8	53.4	47.3	43.1	39.7	36.8	34.4	32.2	30.4	28.8	17.7	13.1	10.6	8.9	7.7	6.8	6.1	5.6	5.1
Grid power V.L 12-100; 1.65V/Z	168.0	161.9	156.0	152.0	147.0	141.0	139.9	136.9	129.0	120.0	111.0	103.0	96.7	91.2	86.4	82.0	78.0	74.0	45.2	35.4	29.1	25.2	22.2	19.7	17.7	16.7	15.4
Grid power V.L 12-150; 1.65V/Z	250.0	242.0	235.0	228.0	221.0	215.0	209.0	203.0	190.0	180.0	170.0	160.0	150.0	142.0	137.0	132.0	128.0	124.0	79.8	65.5	55.2	48.5	43.2	39.2	36.4	34.4	32.5
Grid power V.L 6-200; 1.65V/Z	333.0	323.0	313.0	304.0	295.0	286.0	277.0	268.0	248.0	234.0	219.0	204.0	189.0	174.0	160.0	147.0	135.0	124.0	85.7	70.0	59.8	52.5	46.8	42.2	39.6	37.8	35.6
Grid power V.L 6-250; 1.65V/Z	416.0	403.0	391.0	379.0	369.0	359.0	348.0	339.0	299.0	267.0	237.0	216.0	198.0	184.0	172.0	161.0	152.0	144.0	88.6	73.0	62.0	54.7	49.1	45.3	41.1	39.7	37.4
Grid power V.L 6-300; 1.65V/Z	499.0	484.0	469.0	455.0	442.0	430.0	418.0	407.0	359.0	320.0	284.0	259.0	238.0	224.0	210.0	199.0	189.0	182.0	100.0	83.0	71.0	63.0	57.0	53.0	49.0	47.0	44.0

Discharge current in A / Entlastestrom in A / Ток разряда в А / Courant de décharge in A
 V1.4 / 26.02.2016
 Xonlage (Temperatur): V2.1 (04.08.2013)

Batterie / La batterie	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
Grid power V.L. 12-50-1.87VIZ	76,6	77,2	74,9	72,7	70,7	68,7	66,9	65,2	57,7	51,7	46,0	42,1	38,9	36,1	33,8	31,8	30,0	28,4	17,7	13,1	10,6	8,9	7,7	6,8	6,1	5,6	5,1
Grid power V.L. 12-100-1.87VIZ	159,0	154,0	150,0	145,0	141,0	137,0	134,0	130,0	115,0	103,0	92,0	84,1	77,0	72,0	67,0	63,5	60,0	56,9	35,4	26,3	21,2	17,8	15,4	13,7	12,2	11,1	10,2
Grid power V.L. 12-200-1.87VIZ	230,0	232,0	225,0	218,0	212,0	206,0	201,0	196,0	173,0	155,0	139,0	128,0	117,0	108,0	101,0	95,3	90,0	85,3	53,2	39,4	31,9	26,6	23,2	20,5	18,3	16,7	15,5
Grid power V.L. 6-200-1.87VIZ	318,8	309,0	306,0	291,0	283,0	275,0	268,0	261,0	231,0	202,0	180,0	166,0	154,0	144,0	135,0	127,0	120,0	114,0	79,9	59,5	48,5	39,9	34,2	29,4	24,4	21,8	20,5
Grid power V.L. 6-250-1.87VIZ	398,0	386,0	374,0	364,0	353,0	344,0	335,0	326,0	280,0	236,0	210,0	194,0	181,0	169,0	159,0	150,0	142,0	88,5	65,7	55,1	44,4	38,9	34,2	29,7	25,7	23,4	20,7
Grid power V.L. 6-300-1.87VIZ	478,0	463,0	448,0	436,0	424,0	412,0	402,0	391,0	346,0	302,0	276,0	259,0	249,0	239,0	229,0	219,0	209,0	174,0	108,0	76,8	63,7	53,3	46,2	41,1	36,7	33,4	30,7

Discharge current in A / Entlastestrom in A / Tok pasapaga a / Courant de décharge in A

V1.47/26.02.2018
Voisage [Template]: V2.1 04.09.2013

Batterie / Batterie / La batterie	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
Grid power V L 12-50; 17VIZ	72.2	72.2	70.1	69.0	66.1	64.4	62.7	61.1	54.3	48.9	43.9	40.4	37.4	34.9	32.8	30.9	29.2	27.6	17.7	13.1	10.6	8.9	7.7	6.9	6.1	5.6	5.1
Grid power V L 12-100; 17VIZ	144.0	144.0	140.0	136.0	132.0	128.0	125.0	122.0	108.0	97.8	87.8	80.7	74.8	69.8	65.6	61.8	58.5	55.5	35.4	26.3	21.2	17.6	15.4	13.7	12.2	11.7	11.2
Grid power V L 12-50; 17VIZ	217.0	217.0	210.0	206.0	202.0	198.0	194.0	190.0	168.0	153.0	140.0	129.0	120.0	112.0	105.0	98.3	92.6	87.7	83.3	53.2	39.4	31.9	26.6	23.2	21.2	20.4	19.4
Grid power V L 6-200; 17VIZ	288.0	288.0	280.0	276.0	272.0	268.0	264.0	260.0	234.0	217.0	202.0	187.0	175.0	164.0	154.0	146.0	139.0	133.0	88.6	66.6	55.1	44.4	38.6	34.2	30.6	27.8	25.6
Grid power V L 6-200; 17VIZ	435.0	435.0	420.0	408.0	397.0	386.0	376.0	367.0	326.0	293.0	263.0	242.0	224.0	209.0	197.0	185.0	175.0	167.0	106.0	78.8	65.7	53.3	45.3	41.1	36.7	33.4	30.7

Discharge current in A / Entlastestrom in A / For supply in A / Courant de décharge in A

V1.47.26.02.20.16
Voltage U_{nom} in V, V₂ 1.04.08.2013

Batterie / Battery / La batterie	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
grid power V 12-50; 173V/Z	64,6	64,6	64,6	62,8	61,1	59,5	58,0	56,6	50,6	45,8	41,6	38,5	35,8	33,5	31,6	29,8	28,3	27,0	17,5	13,1	10,6	8,9	7,7	6,8	6,1	5,6	5,1
grid power V 12-100; 173V/Z	129,0	129,0	129,0	125,6	122,0	119,0	116,0	113,0	101,6	91,6	83,1	76,8	72,0	68,0	64,7	61,7	59,7	58,0	34,9	26,3	21,2	17,6	15,4	13,7	12,2	11,1	10,2
grid power V 12-200; 173V/Z	184,0	184,0	184,0	180,0	176,0	173,0	170,0	167,0	150,0	137,0	125,0	118,0	112,0	107,0	101,0	94,7	89,5	85,0	52,4	39,4	31,9	26,6	23,2	20,5	18,3	16,7	15,5
grid power V 12-250; 173V/Z	230,0	230,0	230,0	226,0	222,0	219,0	216,0	213,0	190,0	173,0	160,0	152,0	144,0	138,0	130,0	124,0	118,0	113,0	69,6	52,5	42,5	35,5	30,9	27,4	24,8	22,8	21,6
grid power V 12-300; 173V/Z	276,0	276,0	276,0	272,0	268,0	265,0	262,0	259,0	230,0	208,0	192,0	182,0	175,0	168,0	158,0	149,0	142,0	135,0	87,3	65,7	53,1	44,4	38,6	34,1	30,7	28,6	27,0
grid power V 12-350; 173V/Z	322,0	322,0	322,0	314,0	306,0	299,0	292,0	285,0	250,0	225,0	208,0	195,0	187,0	179,0	170,0	160,0	150,0	142,0	95,0	70,8	56,7	46,9	41,1	36,7	33,4	31,4	30,7
grid power V 12-400; 173V/Z	368,0	368,0	368,0	358,0	349,0	341,0	334,0	327,0	285,0	255,0	235,0	221,0	215,0	201,0	189,0	179,0	170,0	162,0	106,0	78,8	63,7	53,3	46,9	41,1	36,7	33,4	31,4

Discharge current in A / Entlastestrom in A / Tok pasyaga a A / Courant de décharge la A
 V1.4 / 26.02.2018
 Vorläufige (tentative) VZ.1 04.09.2013

Batterie / La baterie	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
Grid power V L 12-50; 1,75V/Z	59,6	59,6	59,6	59,6	59,6	59,6	55,1	53,8	48,1	43,7	40,1	37,2	34,7	32,5	30,7	29,0	27,6	26,3	17,2	13,0	10,5	8,9	7,7	6,8	6,1	5,6	5,1
Grid power V L 12-100; 1,75V/Z	119,0	119,0	119,0	119,0	119,0	119,0	110,0	106,0	96,0	87,4	80,3	74,4	69,4	65,1	61,4	58,1	55,2	52,7	34,3	25,8	21,0	17,8	15,4	13,7	12,2	11,0	10,2
Grid power V L 12-150; 1,75V/Z	179,0	179,0	179,0	179,0	179,0	179,0	165,0	159,0	144,0	131,0	120,0	112,0	104,0	97,6	92,0	87,1	82,8	79,9	51,5	39,9	31,5	26,8	23,0	20,5	18,3	16,7	15,4
Grid power V L 6-200; 1,75V/Z	298,0	298,0	298,0	298,0	298,0	298,0	276,0	269,0	241,0	219,0	201,0	186,0	173,0	163,0	153,0	145,0	138,0	131,0	85,8	64,8	52,5	44,4	38,6	34,2	30,6	27,8	25,6
Grid power V L 6-300; 1,75V/Z	358,0	358,0	358,0	358,0	358,0	358,0	331,0	323,0	279,0	256,0	241,0	223,0	209,0	195,0	184,0	174,0	166,0	159,0	104,0	77,8	63,0	52,3	46,3	41,1	36,7	33,4	30,7

Discharge current in A / Entlastestrom in A / Tok pasapaga w A / Courant de décharge en A
 V1 A / 26.02.2018
 Voltaje (temperatura: 20.1 04.09.2013)

Battery / Batterie / Baterija / Baterija	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
grid power V L 12-50-1.77V/Z	55.9	55.9	55.9	54.5	53.2	51.0	50.8	45.7	41.7	38.5	35.7	33.4	31.4	29.7	28.2	26.8	25.6	16.8	12.6	10.4	8.8	7.6	6.8	6.1	5.6	5.1	
grid power V L 12-100-1.77V/Z	112.0	112.0	112.0	106.0	102.0	97.0	93.5	83.5	78.9	71.5	68.9	62.9	59.4	56.3	53.6	51.1	50.5	33.7	25.6	20.8	17.9	15.3	13.9	12.2	11.7	11.4	
grid power V L 12-150-1.77V/Z	168.0	168.0	168.0	160.0	156.0	150.0	146.0	132.0	125.0	115.0	107.0	100.0	94.3	89.1	84.5	80.4	76.7	50.5	39.3	31.2	26.2	23.6	21.2	19.4	18.2	16.7	15.4
grid power V L 8-300-1.77V/Z	260.0	260.0	260.0	250.0	243.0	233.0	228.0	203.0	192.0	179.0	167.0	157.0	146.0	134.0	126.0	114.0	104.0	68.4	52.2	41.1	31.9	24.0	20.2	17.4	16.4	14.4	13.5
grid power V L 8-250-1.77V/Z	260.0	260.0	260.0	250.0	243.0	233.0	228.0	203.0	192.0	179.0	167.0	157.0	146.0	134.0	126.0	114.0	104.0	68.4	52.2	41.1	31.9	24.0	20.2	17.4	16.4	14.4	13.5
grid power V L 8-500-1.77V/Z	333.0	333.0	333.0	325.0	315.0	306.0	296.0	250.0	231.0	214.0	201.0	185.0	175.0	165.0	155.0	145.0	135.0	89.4	67.7	52.2	40.2	30.2	24.5	20.7	19.7	17.7	16.7

Discharge current in A / Entlastestrom in A / Top paspazka e A / Courant de décharge in A
 V1.4 / 26.02.2018
 Vonage (Amplitude), Vz.1 (04.02.2013)

Battery / Zemera / Dzenera / La baterie	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
grid power V L 12-50; 1,8V/Z	49,5	49,5	49,5	49,5	49,5	48,4	47,3	46,3	42,1	38,6	35,8	33,4	31,4	29,6	28,0	26,6	25,4	24,3	16,2	12,4	10,1	8,6	7,5	6,7	6,0	5,5	5,0
grid power V L 12-100; 1,8V/Z	98,9	98,9	98,9	98,9	98,9	96,7	94,7	92,7	84,2	77,3	71,6	66,6	62,7	59,2	56,0	53,3	50,8	48,5	32,4	24,8	20,2	17,2	15,0	13,3	12,0	10,8	10,1
grid power V L 12-150; 1,8V/Z	148,0	148,0	148,0	148,0	148,0	145,0	142,0	139,0	126,0	116,0	107,0	100,0	94,1	88,7	84,0	79,9	76,2	72,8	48,6	37,2	30,3	25,8	22,5	20,0	18,0	16,4	15,1
grid power V L 6-200; 1,8V/Z	198,0	198,0	198,0	198,0	198,0	193,0	189,0	185,0	165,0	155,0	143,0	134,0	125,0	118,0	112,0	107,0	102,0	97,1	64,9	49,6	40,4	34,3	29,9	26,6	24,0	21,9	20,2
grid power V L 6-250; 1,8V/Z	247,0	247,0	247,0	247,0	247,0	242,0	237,0	232,0	210,0	193,0	179,0	167,0	157,0	148,0	140,0	133,0	127,0	121,0	81,1	61,9	50,6	42,9	37,4	33,3	30,0	27,4	25,2
grid power V L 6-300; 1,8V/Z	297,0	297,0	297,0	297,0	297,0	290,0	284,0	278,0	252,0	232,0	215,0	200,0	186,0	177,0	168,0	160,0	152,0	146,0	97,3	74,3	60,7	51,5	44,9	39,9	36,0	32,8	30,2

Discharge current in A / Entlastestrom in A / Tok razryvna v A / Courant de décharge en A
 V1.4 / 26.02.2018
 Vorlage Template: V2.1 / 04.09.2013

Batterie / La batterie	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
grid power V L 12-50; 1,83VIZ	41,9	41,9	41,9	41,9	41,9	41,5	41,9	41,1	37,7	34,9	32,6	30,6	28,8	27,3	25,9	24,7	23,7	22,7	15,4	11,9	9,8	8,3	7,3	6,5	5,8	5,3	4,9
grid power V L 12-100; 1,83VIZ	83,7	83,7	83,7	83,7	83,7	83,7	83,7	82,2	75,4	69,8	65,1	61,1	57,6	54,6	51,9	49,5	47,3	46,4	30,9	23,8	19,5	16,8	14,5	12,9	11,7	10,8	9,8
grid power V L 12-150; 1,83VIZ	126,0	126,0	126,0	126,0	126,0	126,0	126,0	123,0	113,0	105,0	97,7	91,7	86,5	81,9	77,8	74,2	71,0	68,0	48,3	35,7	29,3	24,9	21,8	19,4	17,5	16,0	14,7
grid power V L 6-200; 1,83VIZ	167,0	167,0	167,0	167,0	167,0	167,0	167,0	164,0	151,0	140,0	130,0	122,0	115,0	108,0	104,0	99,0	94,0	90,7	61,7	47,6	39,0	35,2	28,0	25,8	23,3	21,3	19,8
grid power V L 6-250; 1,83VIZ	209,0	209,0	209,0	209,0	209,0	209,0	209,0	205,0	189,0	175,0	163,0	153,0	144,0	136,0	130,0	124,0	118,0	113,0	77,2	59,5	48,8	41,5	36,3	32,3	29,2	26,6	24,5
grid power V L 6-300; 1,83VIZ	251,0	251,0	251,0	251,0	251,0	251,0	251,0	247,0	226,0	209,0	195,0	183,0	173,0	164,0	156,0	148,0	142,0	136,0	92,6	71,3	58,5	49,5	43,5	39,6	35,8	31,8	29,4

Discharge current in A / Entlastestrom in A / Ток разряда в А / Courant de décharge en A
 V1.4 / 26.02.2018
 Vorlage / Template: V2.1 (04.09.2013)
 Battery / Batterie / Аккумулятор / Батарея / La batterie

	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
grid power V L 12-50; 1,85V/Z	34,8	34,8	34,8	34,8	34,8	34,8	34,8	34,8	34,8	32,4	30,4	28,6	27,0	25,7	24,4	23,4	22,4	21,5	14,8	11,5	9,4	8,1	7,1	6,3	5,7	5,2	4,8
grid power V L 12-100; 1,85V/Z	69,7	69,7	69,7	69,7	69,7	69,7	69,7	69,7	69,7	64,8	60,7	57,2	54,1	51,3	48,9	46,7	44,7	42,9	29,6	22,9	18,9	16,1	14,1	12,6	11,4	10,4	9,6
grid power V L 12-150; 1,85V/Z	105,0	105,0	105,0	105,0	105,0	105,0	105,0	105,0	97,2	91,1	85,7	81,1	77,0	73,3	70,1	67,1	64,4	61,9	44,3	34,4	28,3	24,2	21,2	18,9	17,1	15,6	14,4
grid power V L 6-200; 1,85V/Z	174,0	174,0	174,0	174,0	174,0	174,0	174,0	174,0	139,0	130,0	121,0	114,0	108,0	103,0	97,8	93,4	89,5	85,9	59,1	45,8	37,7	32,2	28,2	25,2	22,7	20,8	19,1
grid power V L 6-250; 1,85V/Z	209,0	209,0	209,0	209,0	209,0	209,0	209,0	209,0	174,0	162,0	152,0	143,0	135,0	128,0	122,0	117,0	112,0	107,0	73,9	57,3	47,2	40,3	35,3	31,4	28,4	26,0	23,9
grid power V L 6-300; 1,85V/Z	209,0	209,0	209,0	209,0	209,0	209,0	209,0	209,0	164,0	164,0	164,0	162,0	162,0	154,0	147,0	140,0	134,0	129,0	86,7	68,8	56,6	48,3	42,3	37,7	34,1	31,2	28,7

Discharge current in A / Entlastestrom in A / Tax pasapaga n A / Courant de décharge in A
 V1.4 / 20.06.2019
 Message (Comptabil) VZ.1 (04.09.2013)

Marque / Bauteil / La batterie	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
grid power V L 12-30; 1,9V/Z	24,4	24,4	24,4	24,4	24,4	24,4	24,4	24,4	24,4	24,4	24,4	23,2	22,0	21,0	20,1	19,3	18,5	17,8	12,6	9,9	8,3	7,1	6,3	5,7	5,1	4,7	4,4
grid power V L 12-100; 1,9V/Z	48,9	48,9	48,9	48,9	48,9	48,9	48,9	48,9	48,9	48,9	48,9	46,3	44,0	42,0	40,2	38,5	37,1	36,7	25,2	19,9	16,6	14,3	12,6	11,3	10,3	9,5	8,8
grid power V L 12-150; 1,9V/Z	73,3	73,3	73,3	73,3	73,3	73,3	73,3	73,3	73,3	73,3	73,3	69,5	66,0	63,0	60,3	57,8	55,6	53,5	37,9	29,8	24,8	21,4	18,9	17,0	15,4	14,2	13,2
grid power V L 6-240; 1,9V/Z	97,8	97,8	97,8	97,8	97,8	97,8	97,8	97,8	97,8	97,8	97,8	92,6	88,1	84,0	80,4	77,1	74,1	71,4	50,5	39,6	33,1	28,5	25,2	22,6	20,6	18,9	17,9
grid power V L 6-250; 1,9V/Z	122,0	122,0	122,0	122,0	122,0	122,0	122,0	122,0	122,0	122,0	122,0	116,0	110,0	105,0	100,0	96,4	92,6	89,2	63,1	49,7	41,4	35,7	31,5	28,3	25,7	23,7	21,9
grid power V L 6-300; 1,9V/Z	147,0	147,0	147,0	147,0	147,0	147,0	147,0	147,0	147,0	147,0	147,0	139,0	132,0	126,0	121,0	116,0	111,0	107,0	75,7	59,6	49,7	42,8	37,9	33,9	30,9	28,4	26,3

Discharge current in A / Entlaststrom in A / Tok pasapaga в A / Courant de décharge in A

V1.4/26.02.2018

Vorlage: Template_VZ.1 04.09.2013

Battery / Batterie / Аккумулятор	3'	4'	5'	6'	7'	8'	9'	10'	15'	20'	25'	30'	35'	40'	45'	50'	55'	1 h	2 h	3 h	4 h	5 h	6 h	7 h	8 h	9 h	10 h
grid power V L 12-50; 1,93V/Z	17,8	17,8	17,8	17,8	17,8	17,8	17,8	17,8	17,8	17,8	17,8	17,8	17,8	17,1	16,4	15,8	15,3	14,8	10,8	8,6	7,3	6,3	5,6	5,1	4,6	4,3	4,0
grid power V L 12-100; 1,93V/Z	35,6	35,6	35,6	35,6	35,6	35,6	35,6	35,6	35,6	35,6	35,6	35,6	35,6	34,1	32,8	31,6	29,5	21,5	17,3	14,5	12,5	11,2	10,2	9,3	8,6	8,0	
grid power V L 12-150; 1,93V/Z	53,4	53,4	53,4	53,4	53,4	53,4	53,4	53,4	53,4	53,4	53,4	53,4	53,4	51,2	49,2	47,5	45,8	44,3	32,3	25,9	21,8	19,0	16,9	15,2	13,9	12,9	12,0
grid power V L 6-200; 1,93V/Z	71,2	71,2	71,2	73,2	71,2	71,2	71,2	71,2	71,2	71,2	71,2	71,2	71,2	68,3	65,7	63,3	61,1	59,1	43,1	34,5	29,1	25,3	22,5	20,3	18,6	17,2	16,0
grid power V L 6-250; 1,93V/Z	89,9	89,9	89,9	89,9	89,9	89,9	89,9	89,9	89,9	89,9	89,9	89,9	89,9	85,3	82,1	79,1	76,3	73,8	53,8	43,1	36,4	31,6	28,1	25,4	23,2	21,5	20,0
grid power V L 6-300; 1,93V/Z	107,0	107,0	107,0	107,0	107,0	107,0	107,0	107,0	107,0	107,0	107,0	107,0	107,0	102,0	98,5	94,9	91,8	88,5	64,6	51,8	43,6	37,9	33,7	30,5	27,9	25,8	24,0



Test Report Physical Test Laboratory

V9145_grid
Version: 6

Prepared by:
Patrick Schluer

Date: 28.03.2019

Released by:
Wilhelm Giller

Page 1 / 63

Typetest grid | power V L Product Range OPzS IEC 60896 – 11



ВЯРНО С ОРИГИНАЛА



Test Report Physical Test Laboratory

 V9145_grid
 Version: 6

 Prepared by:
 Patrick Schluer

Date: 28.03.2019

 Released by:
 Wilhelm Giller

Page 2 / 63

No.	Index	Reference	Page
0	Result summary		3
1	Capacity Test	DIN EN IEC 60896 - 11 Clause 14	15
2	Test of suitability for floating battery operation	DIN EN IEC 60896 - 11 Clause 15	39
3	Endurance in discharge-charge cycles	DIN EN IEC 60896 - 11 Clause 16	44
4	Endurance in overcharge	DIN EN IEC 60896 - 11 Clause 17	47
5	Charge retention test	DIN EN IEC 60896 - 11 Clause 18	50
6	Short-circuit current and internal resistance determination	DIN EN IEC 60896 - 11 Clause 19	56

Remark: HOPPECKE Batterien GmbH & Co. KG renamed the cells with OPzS design to its new brand **grid | power V L**. The names of OPzS and **grid | power V L** are referring to each other directly and there is no technical difference. The present type test which is ongoing is being continued with the current OPzS design and this name conversion has no influence on the test itself.

ВЯРНО С ОРИГИНАЛА



Test Report Physical Test Laboratory

V9145_grid Prepared by: Date: 28.03.2019 Released by: Page 3 / 63
Version: 6 Patrick Schluer Wilhelm Giller

Result summary:

No	Test	Results																									
1	Capacity test	<table border="1"> <thead> <tr> <th></th> <th>C10 [%]</th> <th>C5 [%]</th> <th>C3 [%]</th> <th>C1 [%]</th> </tr> </thead> <tbody> <tr> <td>6 OPzS 300</td> <td>108.8 ⁽²⁾</td> <td>114.7 ⁽¹⁾</td> <td>113.1 ⁽²⁾</td> <td>121.3 ⁽¹⁾</td> </tr> <tr> <td>7 OPzS 490</td> <td>106.9 ⁽¹⁾</td> <td>104.4 ⁽¹⁾</td> <td>103.3 ⁽¹⁾</td> <td>112.8 ⁽¹⁾</td> </tr> <tr> <td>6 OPzS 600</td> <td>105.9 ⁽²⁾</td> <td>108.3 ⁽¹⁾</td> <td>109.9 ⁽¹⁾</td> <td>120.6 ⁽¹⁾</td> </tr> <tr> <td>12 OPzS 1500</td> <td>112.0 ⁽²⁾</td> <td>112.0 ⁽¹⁾</td> <td>116.3 ⁽²⁾</td> <td>137.1 ⁽¹⁾</td> </tr> </tbody> </table>		C10 [%]	C5 [%]	C3 [%]	C1 [%]	6 OPzS 300	108.8 ⁽²⁾	114.7 ⁽¹⁾	113.1 ⁽²⁾	121.3 ⁽¹⁾	7 OPzS 490	106.9 ⁽¹⁾	104.4 ⁽¹⁾	103.3 ⁽¹⁾	112.8 ⁽¹⁾	6 OPzS 600	105.9 ⁽²⁾	108.3 ⁽¹⁾	109.9 ⁽¹⁾	120.6 ⁽¹⁾	12 OPzS 1500	112.0 ⁽²⁾	112.0 ⁽¹⁾	116.3 ⁽²⁾	137.1 ⁽¹⁾
	C10 [%]	C5 [%]	C3 [%]	C1 [%]																							
6 OPzS 300	108.8 ⁽²⁾	114.7 ⁽¹⁾	113.1 ⁽²⁾	121.3 ⁽¹⁾																							
7 OPzS 490	106.9 ⁽¹⁾	104.4 ⁽¹⁾	103.3 ⁽¹⁾	112.8 ⁽¹⁾																							
6 OPzS 600	105.9 ⁽²⁾	108.3 ⁽¹⁾	109.9 ⁽¹⁾	120.6 ⁽¹⁾																							
12 OPzS 1500	112.0 ⁽²⁾	112.0 ⁽¹⁾	116.3 ⁽²⁾	137.1 ⁽¹⁾																							
2	Test of suitability for floating battery operation ⁽³⁾	Density variation: passed Voltage variation: passed Water consumption: passed Capacity test: passed ⁽¹⁾⁽²⁾																									
3	Endurance in discharge-charge cycles ⁽³⁾	Test passed (requirement > 100 cycles) in progress – 663 cycles ⁽¹⁾⁽²⁾																									
4	Endurance in overcharge ⁽³⁾	18 units ⁽¹⁾⁽²⁾ , test passed																									
5	Charge retention test ⁽³⁾	Capacity loss 1.2% per month ⁽¹⁾⁽²⁾																									
6	Short-circuit current and internal resistance determination	<table border="1"> <thead> <tr> <th></th> <th>Ri [mOhm]</th> <th>ISC [A]</th> </tr> </thead> <tbody> <tr> <td>6 OPzS 300 ⁽¹⁾</td> <td>0.569</td> <td>3480</td> </tr> <tr> <td>7 OPzS 490 ⁽¹⁾</td> <td>0.437</td> <td>4504</td> </tr> <tr> <td>6 OPzS 600 ⁽¹⁾</td> <td>0.440</td> <td>4495</td> </tr> <tr> <td>12 OPzS 1500 ⁽¹⁾</td> <td>0.218</td> <td>9072</td> </tr> </tbody> </table>		Ri [mOhm]	ISC [A]	6 OPzS 300 ⁽¹⁾	0.569	3480	7 OPzS 490 ⁽¹⁾	0.437	4504	6 OPzS 600 ⁽¹⁾	0.440	4495	12 OPzS 1500 ⁽¹⁾	0.218	9072										
	Ri [mOhm]	ISC [A]																									
6 OPzS 300 ⁽¹⁾	0.569	3480																									
7 OPzS 490 ⁽¹⁾	0.437	4504																									
6 OPzS 600 ⁽¹⁾	0.440	4495																									
12 OPzS 1500 ⁽¹⁾	0.218	9072																									

- (1) Test was witnessed by Mr. C. Hoppe (Surveyor, Essen Operation, DNV GL Maritime)
 (2) Test was reviewed by Mr. C. Hoppe (Surveyor, Essen Operation, DNV GL Maritime)
 (3) The Type Test on the battery type OPzS was done in accordance to IEC 60896 part 11.
 The cells selected for the test (7 OPzS 490 with 70 Ah plate) consist of similar / equal parts as all other cell sizes.

Test Report Physical Test Laboratory

V9145_grid Version: 6 Prepared by: Patrick Schluer Date: 28.03.2019 Released by: Wilhelm Giller Page 4 / 65

Due to the fact that the 50 Ah, 70 Ah , 100 Ah and the 125 Ah plate use the same technology,

- the same kind of grids,
- the same active mass,
- the same separators
- and they differ mainly in dimension,

the results for the life time tests as with the Type Test of 7 OPzS 490 (Test of suitability for floating battery operation, Endurance in discharge-charge cycles, Endurance in overcharge, Charge retention test) can be carried over to the other types.

Due to different electrical values (different capacities) of the plates the following tests will be done with all types:

- capacity test according to IEC 60896-11
- short-circuit current and internal resistance determination

Signatures:

HOPPECKE representatives

Released by:

W. Giller
p. p. Mr. Wilhelm Giller 28.03.19

Manager of
Physical Laboratory

HOPPECKE Batterien
Physikalisches Labor
Bontkirchener Str. 1
59929 Brilon
Deutschland

Prepared by:

P. Schluer
p. p. Mr. Patrick Schluer 28.03.19

Physical
Laboratory

DNV GL representatives

Witnessed/Reviewed by:

p. p. Mr. C. Hoppe

Surveyor, Essen Operation
DNV GL Maritime



Test Report Physical Test Laboratory

V9145_grid
Version: 6

Prepared by:
Patrick Schluer

Date: 28.03.2019

Released by:
Wilhelm Giller

Page 5 / 63

Test location: HOPPECKE Batterien GmbH & Co KG, physical test field

Reference documents: IEC 60896 – 11

Test object:

Batt. 1:

- 6 cells of the type **6 OPzS 300** (50 Ah plate) with original connectors, connected in series.
- Cell- no.: 01-06
- Manufacturing identification no.: 8865001

Batt. 2:

- 3 cells of the type **6 OPzS 300** (50 Ah plate) with original connectors, connected in series.
- Cell- no.: 07-09
- Manufacturing identification no.: 8865001

Batt. 3:

- 6 cells of the type **7 OPzS 490** (70 Ah plate) with original connectors, connected in series.
- Cell- no.: 10-15
- Manufacturing identification no.: 8865002

Batt. 4:

- 3 cells of the type **7 OPzS 490** (70 Ah plate) with original connectors, connected in series.
- Cell- no.: 16-18
- Manufacturing identification no.: 8865002

Batt. 5:

- 6 cells of the type **7 OPzS 490** (70 Ah plate) with original connectors, connected in series.
- Cell- no.: 19-24
- Manufacturing identification no.: 8865002

Test Report Physical Test Laboratory

V9145_grid
Version: 6

Prepared by:
Patrick Schluer

Date: 28.03.2019

Released by:
Wilhelm Giller

Page 6 / 63

Batt. 6:

- 6 cells of the type **7 OPzS 490** (70 Ah plate) with original connectors, connected in series.
- Cell- no.: 25-30
- Manufacturing identification no.: 8865002

Batt. 7:

- 6 cells of the type **7 OPzS 490** (70 Ah plate) with original connectors, connected in series.
- Cell- no.: 31-36
- Manufacturing identification no.: 8865002

Batt. 10:

- 6 cells of the type **6 OPzS 600** (100 Ah plate) with original connectors, connected in series.
- Cell- no.: 46-51
- Manufacturing identification no.: 8865003

Batt. 11:

- 3 cells of the type **6 OPzS 600** (100 Ah plate) with original connectors, connected in series.
- Cell- no.: 52-54
- Manufacturing identification no.: 8865003

Batt. 12:

- 6 cells of the type **12 OPzS 1500** (125 Ah plate) with original connectors, connected in series.
- Cell- no.: 55-60
- Manufacturing identification no.: 8865004

Batt. 13:

- 3 cells of the type **12 OPzS 1500** (125 Ah plate) with original connectors, connected in series.
- Cell- no.: 61-63
- Manufacturing identification no.: 8865004

Test Report Physical Test Laboratory

V9145_grid
Version: 6

Prepared by:
Patrick Schluer

Date: 28.03.2019

Released by:
Wilhelm Giller

Page 7 / 63

Test procedure:

Batt.- type:	Batt- no.:	Test- procedure
6 OPzS 300	1	C10 + C5 + C3 + C1
	2	Short-circuit current
7 OPzS 490	3	C10 + 60896 - 11 / 16
	4	Short-circuit current
	5	C5 + 60896 – 11 / 18
	6	C3 + 60896 – 11 / 15
	7	C1 + 60896 – 11 / 17
6 OPzS 600	10	C10 + C5 + C3 + C1
	11	Short-circuit current
12 OPzS 1500	12	C10 + C5 + C3 + C1
	13	Short-circuit current

Test period:

Tests start February 2017

Test Report Physical Test Laboratory

V9145_grid Prepared by:
Version: 6 Patrick Schluer

Date: 28.03.2019

Released by:
Wilhelm Giller

Page 8 / 63

Used testing sets:

Batt.-type:	Test	Unit:	Type:	Structure-no.:	Next calibration date:	
6 OPzS 300	Capacity test	Battery Tester	Moran 264 100A/20V	1814080179	April 2017	
		C10	Chart-recorder	6 Channel	1814022210	July 2017
		C5	Density meter	DMA 35	1813010018	August 2017
	C3	Density meter	DMA 35	1813010018	August 2017	
	Capacity test	C1	Battery Tester	BasyTec 001 360A/20V	1814080220	April 2017
		C1	Chart-recorder	Yokogawa DX 220	1814060039	August 2017
		C1	Shunt	600 A / 60 mV	1814040157	June 2017
		C1	Thermometer	PT 100	1814050067	September 2017
		C1	Density meter	DMA 35	1813010018	August 2017
	Short circuit and D.C. internal resistance	C1	Battery Tester	Digatron 153 2000A/20V	1814080002	August 2017
		C1	Chart-recorder	Yokogawa DX 208	1814060036	August 2017
		C1	Shunt	2000 A / 200 mV	1814040091	June 2018
		C1	Thermometer	PT 100	1814050081	March 2017
		C1	Densitymeter	DMA 35	1813010018	August 2017

Test Report Physical Test Laboratory

V9145_grid Prepared by: Date: 28.03.2019 Released by: Page 9 / 63
 Version: 6 Patrick Schluer Wilhelm Giller

Batt.-type:	Test	Unit:	Type:	Structure-no.:	Next calibration date:
7 OPzS 490	Capacity test C10	Battery Tester	Moran 208 100A/20V	1814080120	July 2017
		Chart-recorder	6 Channel	1814021206	July 2017
		Density meter	DMA 35	1813010018	August 2017
	Capacity test C5	Battery Tester	Moran 271 200A/20V	1814080147	April 2017
		Chart-recorder	6 Channel	1814021110	July 2017
		Density meter	DMA 35	1813010018	August 2017
	Capacity test C3	Battery Tester	Moran 272 200A/20V	1814080148	April 2017
		Chart-recorder	6 Channel	1814022202	July 2017
		Density meter	DMA 35	1813010018	August 2017
	Capacity test C1	Battery Tester	Digatron 351 1000A/20V	1814080004	August 2017
		Chart-recorder	Yokogawa DX 230	1814060038	August 2017
		Shunt	500 A / 60 mV	1814040141	June 2017
		Thermometer	PT 100	1814050121	September 2017
		Densitymeter	DMA 35	1813010018	August 2017

Test Report Physical Test Laboratory

V9145_grid Prepared by: Date: 28.03.2019 Released by: Page 10 / 63
 Version: 6 Patrick Schluer Wilhelm Giller

Batt.-type:	Test	Unit:	Type:	Structure-no.:	Next calibration date:
7 OPzS 490	Test of suitability for floating battery operation C10 - Start	Battery Tester	Moran 208 100A/20V	1814080120	July 2017
		Chart-recorder	6 Channel	1814021206	July 2017
		Density meter	DMA 35	1813010018	August 2017
	Test of suitability for floating battery operation C10 - End	Battery Tester	Moran 270 100A/20V	1814080120	July 2018
		Chart-recorder	6 Channel	1814021107	August 2018
		Density meter	DMA 35	1813010018	August 2018
	Endurance in discharge-charge cycles	Battery Tester	Moran 307 200A/20V	1814080185	April 2017
		Chart-recorder	6 Channel	1814022203	July 2017
		Density meter	DMA 35	1813010018	August 2017
	Endurance in overcharge C1 – Start	Battery Tester	Digatron 351 1000A/20V	1814080004	August 2017
		Chart-recorder	Yokogawa DX 230	1814060038	August 2017
		Shunt	500 A / 60 mV	1814040141	June 2017
		Thermometer	PT 100	1814050121	September 2017
		Densitometer	DMA 35	1813010018	August 2017
	Endurance in overcharge Overcharge	Battery Tester	Moran 260 50A/20V	1814080175	April 2017
Chart-recorder		6 Channel	1814022207	July 2017	
Density meter		DMA 35	1813010018	August 2017	

Test Report Physical Test Laboratory

V9145_grid Prepared by: Date: 28.03.2019 Released by: Page 11 / 63
 Version: 6 Patrick Schluer Wilhelm Giller

Batt.-type:	Test	Unit:	Type:	Structure-no.:	Next calibration date:
7 OPzS 490	Charge retention test C10 Start	Battery Tester	Moran 208 100A/20V	1814080120	July 2017
		Chart-recorder	6 Channel	1814021206	July 2017
		Density meter	DMA 35	1813010018	August 2017
	Charge retention test C10 End	Battery Tester	Moran 303 100A/20V	1814080196	Mai 2018
		Chart-recorder	6 Channel	1814021112	July 2017
		Density meter	DMA 35	1813010018	August 2017
	Short circuit and D.C. internal resistance	Battery Tester	Digatron 153 2000A/20V	1814080002	August 2017
		Chart-recorder	Yokogawa DX 208	1814060036	August 2017
		Shunt	2000 A / 200 mV	1814040091	June 2018
		Thermometer	PT 100	1814050081	March 2017
		Densitometer	DMA 35	1813010018	August 2017

Test Report Physical Test Laboratory

V9145_grid Prepared by:
Version: 6 Patrick Schluer

Date: 28.03.2019

Released by:
Wilhelm Giller

Page 12 / 63

Batt.-type:	Test	Unit:	Type:	Structure-no.:	Next calibration date:
6 OPzS 600	Capacity test C10 C5	Battery Tester	Moran 307 200A/20V	1814080185	April 2017
		Chart-recorder	6 Channel	1814022203	July 2017
		Density meter	DMA 35	1813010018	August 2017
	Capacity test C3	Battery Tester	Digatron 351 1000A/20V	1814080004	August 2017
		Chart-recorder	Yokogawa MV 2000	1814060048	July 2017
		Shunt	300 A / 60 mV	1814040181	June 2017
		Thermometer	PT 100	1814050135	September 2017
		Densitometer	DMA 35	1813010018	August 2017
	Capacity test C1	Battery Tester	Digatron 351 1000A/20V	1814080004	August 2017
		Chart-recorder	Yokogawa MW 100	1814060056	September 2017
		Shunt	600 A / 60 mV	1814040217	January 2018
		Thermometer	PT 100	1814050135	September 2017
		Densitometer	DMA 35	1813010018	August 2017
	Short circuit and D.C. internal resistance	Battery Tester	Digatron 153 2000A/20V	1814080002	August 2017
		Chart-recorder	Yokogawa DX 208	1814060036	August 2017
		Shunt	2000 A / 200 mV	1814040091	June 2018
		Thermometer	PT 100	1814050081	March 2017
		Densitometer	DMA 35	1813010018	August 2017

Test Report Physical Test Laboratory

 V9145_grid Prepared by:
 Version: 6 Patrick Schluer

Date: 28.03.2019

 Released by:
 Wilhelm Giller

Page 13 / 63

Batt.-type:	Test	Unit:	Type:	Structure-no.:	Next calibration date:
12 OPzS 1500	Capacity test C10	Battery Tester	Moran 272 200A/20V	1814080148	April 2017
		Chart-recorder	6 Channel	1814022202	July 2017
		Density meter	DMA 35	1813010018	August 2017
	Capacity test C5	Battery Tester	Benning 303 500A/100V	1814080202	June 2017
		Chart-recorder	Yokogawa MV 2000	1814060048	July 2017
		Shunt	500 A / 100 mV	1814040201	November 2017
		Thermometer	PT 100	1814050075	September 2017
		Densitometer	DMA 35	1813010018	August 2017
	Capacity test C3	Battery Tester	Digatron 351 1000A/20V	1814080004	August 2017
		Chart-recorder	Yokogawa DX 230	1814060044	August 2017
		Shunt	1000 A / 100 mV	1814040203	November 2017
		Thermometer	PT 100	1814050131	September 2017
		Densitometer	DMA 35	1813010018	August 2017

Test Report Physical Test Laboratory

V9145_grid Prepared by:
Version: 6 Patrick Schluer

Date: 28.03.2019

Released by:
Wilhelm Giller

Page 14 / 63

Batt.-type:	Test	Unit:	Type:	Structure-no.:	Next calibration date:
12 OPzS 1500	Capacity test	Battery Tester	Digatron 153 2000A/20V	1814080002	August 2017
		Chart-recorder	Yokogawa DX 230	1814060044	August 2017
		Shunt	2000 A / 200 mV	1814040091	June 2018
		Thermometer	PT 100	1814050075	September 2017
		Densitymeter	DMA 35	1813010018	August 2017
	Short circuit and D.C. internal resistance	Battery Tester	Digatron 051 3000A/20V Digatron 153 2000A/20V	1814080201 1814080002	Mai 2017 August 2017
		Chart-recorder	Yokogawa DX 208	1814060041	August 2017
		Shunt	6000 A / 60 mV	1814040025	November 2018
		Thermometer	PT 100	1814050131	September 2017
		Densitymeter	DMA 35	1813010018	August 2017